



- ① WATER MAIN
- ② 4.5' MIN. COVER
- ③ O.D. + 24"
- ④ BEDDING
- ⑤ MASON SAND
- ⑥ TRENCH WALL
- ⑦ BACKFILL
- ⑧ CLOSED CELL EXTRUDED POLYSTYRENE FOAM BOARDS

NOTES:  
 A. IF COVER IS LESS THAN 4.5' EXTEND CLOSED CELL EXTRUDED POLYSTYRENE BOARDS DOWN BOTH SIDES TO PIPE FLOWLINE.  
 B. POLYETHYLENE FILM ENVELOPE NOT SHOWN.

RIGID INSULATION

# UTILITY PIPE INSULATION  
 C### NTS

Revisions:

No.	Date:	Description:

Graphic Scale	
DFD Number	
Set Type	
Date Issued	8/1/2017
Sheet Number	