

Bulk Sample Data - Asbestos						Export to Excel	Home
A: NATURAL RESOURCES - I: SOUTHEASTERN REGION HDQRTS - B: 04221 - OFFICE - SERVICE CENTER							
Inspection Date: 10/24/2006 Data Entry Complete: 11/6/2006 Last Revision Date: 11/6/2006							
Sample #	Room	Location in Room	Material Code	Material Desc.	Comments	Lab Result	
001	302	West wall	MDWC	Drywall/Joint Compound		Non-ACM	
002	113	North wall	MDWC	Drywall/Joint Compound		Non-ACM	
003	231	North wall	MDWC	Drywall/Joint Compound		Non-ACM	
004	05		MSCT-1	2' x 4' Ceiling Tile (Craters)		Non-ACM	
005	112		MSCT-1	2' x 4' Ceiling Tile (Craters)		Non-ACM	
006	200		MSCT-1	2' x 4' Ceiling Tile (Craters)		Non-ACM	
007	128	West wall	MV4	4" Wallbase and Mastic (Brown)		Non-ACM	
008	30	West wall	MV4	4" Wallbase and Mastic (Brown)		Non-ACM	
009	231	East wall	MV4	4" Wallbase and Mastic (Brown)		Non-ACM	
010	06		MSCT-2	2" x 4" Ceiling Tile (Drywall Panels)		Non-ACM	
011	06		MSCT-2	2" x 4" Ceiling Tile (Drywall Panels)		Non-ACM	
A: NATURAL RESOURCES - I: SOUTHEASTERN REGION HDQRTS - B: 04221 - OFFICE - SERVICE CENTER							
Inspection Date: 10/24/2006 Data Entry Complete: 11/6/2006 Last Revision Date: 11/6/2006							
Sample #	Room	Location in Room	Material Code	Material Desc.	Comments	Lab Result	
012	07		MSCT-2	2" x 4" Ceiling Tile (Drywall Panels)		Non-ACM	
013	103		MSCT-3	2' x 2' Ceiling Tile (Rough)		Non-ACM	
014	128		MSCT-3	2' x 2' Ceiling Tile (Rough)		Non-ACM	
015	130		MSCT-3	2' x 2' Ceiling Tile (Rough)		Non-ACM	
016	119		MCT-1	1' x 1' Ceiling Tile		Non-ACM	
017	119		MCT-1	1' x 1' Ceiling Tile		Non-ACM	
018	120		MCT-1	1' x 1' Ceiling Tile		Non-ACM	
019	119		MF9Y	9" x 9" Floor Tile (Grey) and Mastic (Black)	Floor Tile	ACM	

<u>020</u>	119		<u>MF9Y</u>	<u>9" x 9" Floor Tile (Grey) and Mastic (Black)</u>	Floor Tile	ACM
<u>021</u>	120		<u>MF9Y</u>	<u>9" x 9" Floor Tile (Grey) and Mastic (Black)</u>	Floor Tile	ACM
<u>022</u>	124		<u>MSCT-4</u>	<u>2' x 4' Ceiling Tile (Holes)</u>		Non-ACM
A: NATURAL RESOURCES - I: SOUTHEASTERN REGION HDQRTS - B: 04221 - OFFICE - SERVICE CENTER Inspection Date: 10/24/2006 Data Entry Complete: 11/6/2006 Last Revision Date: 11/6/2006						
Sample #	Room	Location in Room	Material Code	Material Desc.	Comments	Lab Result
<u>023</u>	139		<u>MSCT-4</u>	<u>2' x 4' Ceiling Tile (Holes)</u>		Non-ACM
<u>024</u>	139		<u>MSCT-4</u>	<u>2' x 4' Ceiling Tile (Holes)</u>		Non-ACM
<u>025</u>	113		<u>MCM</u>	<u>Carpet Mastic (Tan)</u>		Non-ACM
<u>026</u>	120		<u>MCM</u>	<u>Carpet Mastic (Tan)</u>		Non-ACM
<u>027</u>	119		<u>MCM</u>	<u>Carpet Mastic (Tan)</u>		Non-ACM
<u>028</u>	303		<u>TXB</u>	<u>Exhaust Breeching</u>		Non-ACM
<u>029</u>	303		<u>TXB</u>	<u>Exhaust Breeching</u>		Non-ACM
<u>030</u>	303		<u>TXB</u>	<u>Exhaust Breeching</u>		Non-ACM
<u>031</u>	30		<u>MF12N</u>	<u>12" x 12" Floor Tile (Brown)</u>		ACM
<u>031</u>	30		<u>MF12N</u>	<u>12" x 12" Floor Tile (Brown)</u>	Black mastic	ACM
<u>032</u>	137		<u>MF12N</u>	<u>12" x 12" Floor Tile (Brown)</u>		ACM
A: NATURAL RESOURCES - I: SOUTHEASTERN REGION HDQRTS - B: 04221 - OFFICE - SERVICE CENTER Inspection Date: 10/24/2006 Data Entry Complete: 11/6/2006 Last Revision Date: 11/6/2006						
Sample #	Room	Location in Room	Material Code	Material Desc.	Comments	Lab Result
<u>032</u>	137		<u>MF12N</u>	<u>12" x 12" Floor Tile (Brown)</u>	Black mastic	ACM
<u>033</u>	232		<u>MF12N</u>	<u>12" x 12" Floor Tile (Brown)</u>		ACM
<u>033</u>	232		<u>MF12N</u>	<u>12" x 12" Floor Tile (Brown)</u>	Black mastic	ACM
<u>034</u>	120	South wall	<u>SP1</u>	<u>Plaster</u>		Non-ACM
<u>035</u>	219	South wall	<u>SP1</u>	<u>Plaster</u>		Non-ACM
<u>036</u>	221	North wall	<u>SP1</u>	<u>Plaster</u>		Non-ACM
<u>037</u>	30		<u>MF12Y</u>	<u>12" x 12" Floor Tile (Grey) and Mastic (Black)</u>		Non-ACM
				<u>12" x 12" Floor Tile</u>		

<u>037</u>	30		<u>MF12Y</u>	<u>(Grey) and Mastic (Black)</u>	Mastic Trace	Non-ACM
<u>038</u>	30		<u>MF12Y</u>	<u>12" x 12" Floor Tile (Grey) and Mastic (Black)</u>		Non-ACM
<u>038</u>	30		<u>MF12Y</u>	<u>12" x 12" Floor Tile (Grey) and Mastic (Black)</u>	Mastic trace	Non-ACM
<u>039</u>	30		<u>MF12Y</u>	<u>12" x 12" Floor Tile (Grey) and Mastic (Black)</u>		Non-ACM

**A: NATURAL RESOURCES - I: SOUTHEASTERN REGION HDQRTS - B:
04221 - OFFICE - SERVICE CENTER**
**Inspection Date: 10/24/2006 Data Entry Complete: 11/6/2006 Last
Revision Date: 11/6/2006**

Sample #	Room	Location in Room	Material Code	Material Desc.	Comments	Lab Result
<u>039</u>	30		<u>MF12Y</u>	<u>12" x 12" Floor Tile (Grey) and Mastic (Black)</u>	Mastic Trace	Non-ACM
<u>040</u>	26		<u>MTL</u>	<u>Labtops</u>		Non-ACM
<u>041</u>	17		<u>MTL</u>	<u>Labtops</u>		Non-ACM
<u>042</u>	14		<u>MTL</u>	<u>Labtops</u>		Non-ACM