

Building Summary

Export to Excel

Home

Agency	NATURAL RESOURCES
Institution	SOUTHEASTERN REGION HDQRTS
Building	04221 - OFFICE - SERVICE CENTER
Inspection Date: 10/24/2006 Data Entry Complete: 11/6/2006 Last Revision Date: 11/6/2006	

Building Summary - Asbestos

Building Log First Comment	(October 27, 2006) The non-destructive nature of this survey limited the identification and qualification of suspect ACM to readily accessible materials. Any hidden ACM (including but not limited to thermal system insulation) have not been identified by this survey.
----------------------------	--

[Click Here to See If Additional Comments Available](#)

ACM Materials		
HM Code	Description	ACM/Assumed ACM
<u>MCTM</u>	<u>Ceramic Tile Mastic</u>	Assumed ACM
<u>MF12N</u>	<u>12" x 12" Floor Tile (Brown)</u>	ACM
<u>MF9Y</u>	<u>9" x 9" Floor Tile (Grey) and Mastic (Black)</u>	ACM
<u>MQTM</u>	<u>Quarry Tile Mastic</u>	Assumed ACM

Non-ACM Materials		
HM Code	Description	Non-ACM
<u>INA</u>		Non-ACM
<u>MCM</u>	<u>Carpet Mastic (Tan)</u>	Non-ACM
<u>MCT-1</u>	<u>1' x 1' Ceiling Tile</u>	Non-ACM
<u>MDWC</u>	<u>Drywall/Joint Compound</u>	Non-ACM
<u>MF12Y</u>	<u>12" x 12" Floor Tile (Grey) and Mastic (Black)</u>	Non-ACM
<u>MSCT-1</u>	<u>2' x 4' Ceiling Tile (Craters)</u>	Non-ACM
<u>MSCT-2</u>	<u>2' x 4" Ceiling Tile (Drywall Panels)</u>	Non-ACM
<u>MSCT-3</u>	<u>2' x 2' Ceiling Tile (Rough)</u>	Non-ACM
<u>MSCT-4</u>	<u>2' x 4' Ceiling Tile (Holes)</u>	Non-ACM
<u>MTL</u>	<u>Labtops</u>	Non-ACM

A: NATURAL RESOURCES - I: SOUTHEASTERN REGION HDQRTS - B: 04221 - OFFICE - SERVICE CENTER

Inspection Date: 10/24/2006 Data Entry Complete: 11/6/2006 Last Revision Date: 11/6/2006

HM Code	Description	Non-ACM
<u>MV4</u>	<u>4" Wallbase and Mastic (Brown)</u>	Non-ACM
<u>NSM</u>		Non-ACM
<u>SP1</u>	<u>Plaster</u>	Non-ACM
<u>TXB</u>	<u>Exhaust Breaching</u>	Non-ACM

Floor Summary of ACM				
Floor #	HM Code	Description	Quantity	Units
1	MCTM	Ceramic Tile Mastic	2034	SF
	MF12N	12" x 12" Floor Tile (Brown)	90	SF
	MF9Y	9" x 9" Floor Tile (Grey) and Mastic (Black)	2250	SF
	MQTM	Quarry Tile Mastic	2950	SF
2	MCTM	Ceramic Tile Mastic	1168	SF
	MF12N	12" x 12" Floor Tile (Brown)	72	SF
3	MF12N	12" x 12" Floor Tile (Brown)	70	SF
Attic	MF12N	12" x 12" Floor Tile (Brown)	48	SF
Basement	MCTM	Ceramic Tile Mastic	1560	SF
	MF12N	12" x 12" Floor Tile (Brown)	56	SF