

WISCONSIN DHS ANNUAL 2026 SYSTEM RECORD OF INSPECTION AND TESTING

System Name: DHS 1WW NOTIFIER Building(s): DEPARTMENT OF HEALTH SERVICES
Panel Name: 01 - 1WW DHS NOTIFIER
Supplemental Form(s) Attached: Yes Tested in Accordance with NFPA72 2022 Standards.

1. PROPERTY INFORMATION

Name of property: DEPARTMENT OF HEALTH SERVICES (4433-53703-00035)
Address: 1 WEST WILSON, MADISON WI.
Description of property: STATE OFFICE BUILDING
Name of property representative: STATE OF WISCONSIN (30134997), HEATH HAUG
Address: 101 E WILSON ST, MADISON, WI 53703-3405
Phone: None Fax: None E-mail: None

2. TESTING AND MONITORING INFORMATION

Testing organization: SIEMENS Organization License No.: NA
Address: 6737 W Washington Street, Suite 3125, Milwaukee, WI 53214
Phone: 414-475-3700 Fax: None E-mail: NA
Start Date/Time: 2026-01-26 0700 Completion Date/Time: 2026-01-30 1300
Contract Info: STATE OF WISCONSIN (2600137934) Notification Number: 5102905694
Monitoring organization: CAPITOL POLICE
Address: NA
Phone: 1-608-266-8797 Fax: NA E-mail: NA
Account number: NA Phone line One: NA Phone line Two: NA
Means of transmission: Digital
Entity to which alarms are retransmitted: NA Phone: NA
Dialer Manufacturer: NA Model Number: NA

3. DOCUMENTATION

On-site location of the required record documents and site-specific software: IN MAINTENANCE AND FACP ROOM

4. DESCRIPTION OF SYSTEM OR SERVICE

4.1 Control Unit

System Name: DHS 1WW NOTIFIER Panel Name: 01 - 1WW DHS NOTIFIER
Panel Location and Address: FL. B-1 ROOM 159, 1 WEST WILSON ST., MADISON WI. 53703
Manufacturer: NOTIFIER Model number: FCI 3030

4.2 Software and Firmware

Firmware revision number:

4.3 System Power

4.3.1 Primary (Main) Power

Nominal voltage: Amps: Location: FL. B-1 ROOM 159
Overcurrent protection type: Amps:
Disconnecting means location:

4.3.2 Secondary Power

Type: Storage Battery Location: FL. B-1 ROOM 159
Battery type (if applicable): Dry Cell Manufactured Date: 2019-05-01
Calculated capacity of batteries to drive the system:
In standby mode (hours): 24 In alarm mode (minutes): 15

4.4 Notification Appliance Power Extender Panels

4.4.1 Primary Power

ID	Location	Input Volts	Panel Amps	Over-current Type	Over-current Amps	Primary Supply Location	Disconnect Location
01:01:01:01:NAC-01	B464						
01:01:01:01:NAC-02	B382-384						
01:01:01:01:NAC-03	B382-384						
01:01:01:01:NAC-04	167U						
01:01:01:01:NAC-05	167U						
01:01:01:01:NAC-06	1st Fl. N.E. U1 STAIR ELECTRICAL RM						
01:01:01:01:NAC-07	267U						
01:01:01:01:NAC-08	267U						
01:01:01:01:NAC-09	B174Y						
01:01:01:01:NAC-10	B174Y						
01:01:01:01:NAC-11	367U						
01:01:01:01:NAC-12	367U (TOP)						
01:01:01:01:NAC-13	367U (BOTTOM)						
01:01:01:01:NAC-14	467 (TOP)						
01:01:01:01:NAC-15	467 (BOTTOM)						
01:01:01:01:NAC-16	567 (TOP)						
01:01:01:01:NAC-17	567 (BOTTOM)						
01:01:01:01:NAC-18	651Y (TOP)						
01:01:01:01:NAC-19	651Y (BOTTOM LEFT)						
01:01:01:01:NAC-20	651Y (BOTTOM RIGHT)						
01:01:01:01:NAC-21	751Z						
01:01:01:01:NAC-23	951Y						
01:01:01:01:T-01	B271 (LEFT)						
01:01:01:01:T-02	B271 (CENTER)						
01:01:01:01:T-03	B271 (RIGHT)						
01:01:01:01:T-04	751Z						
01:FACP B1-RM. 159	B1-ROOM 159						

4.4.2 Secondary Power

ID	Location	Battery Type	Manufactured Date	Voltage Rating	Amp Rating	Standby Hours	Alarm Minutes
01:01:01:01:NAC-01	B464	SLA	2023-10-07	12 VDC	7AH	24 HRS	15 MIN
01:01:01:01:NAC-02	B382-384	SLA	2021-11-02	12 VDC	8 AH	24 HRS	15 MIN
01:01:01:01:NAC-03	B382-384	SLA	2023-10-22	12 VDC	8 AH	24 HRS	15 MIN
01:01:01:01:NAC-04	167U	SLA	2023-01-02	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-05	167U	SLA	2023-01-02	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-06	1st Fl. N.E. U1 STAIR ELECTRICAL RM	SLA	2024-11-18	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-07	267U	SLA	2023-01-02	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-08	267U	SLA	2022-05-25	12 VDC	12AH	24 HRS	15 MIN
01:01:01:01:NAC-09	B174Y	SLA	2023-01-02	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-10	B174Y	SLA	2022-05-25	12 VDC	12AH	24 HRS	15 MIN
01:01:01:01:NAC-11	367U	SLA	2022-09-10	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-12	367U (TOP)	SLA	2022-09-10	12VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-13	367U (BOTTOM)	SLA	2022-09-10	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-14	467 (TOP)	SLA	2023-08-23	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-15	467 (BOTTOM)	SLA	2022-02-25	12 VDC	12AH	24 HRS	15 MIN
01:01:01:01:NAC-16	567 (TOP)	SLA	2022-03-22	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-17	567 (BOTTOM)	SLA	2023-01-02	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-18	651Y (TOP)	SLA	2024-11-18	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-19	651Y (BOTTOM LEFT)	SLA	2022-09-10	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-20	651Y (BOTTOM RIGHT)	SLA	2024-11-18	12 VDC	12AH	24 HRS	15 MIN
01:01:01:01:NAC-21	751Z	SLA	2021-11-02	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:NAC-23	951Y	SLA	2022-05-12	12 VDC	8AH	24 HRS	15 MIN
01:01:01:01:T-01	B271 (LEFT)	SLA	2022-09-10	12 VDC	55AH	24 HRS	15 MIN
01:01:01:01:T-02	B271 (CENTER)	VRLA	2023-05-31	12 VDC	80AH	24 HRS	15 MIN
01:01:01:01:T-03	B271 (RIGHT)	VRLA	2023-05-01	12 VDC	80AH	24 HRS	15 MIN
01:01:01:01:T-04	751Z	SLA	2023-11-17	12 VDC	26AH	24 HRS	15 MIN
01:FACP B1-RM. 159	B1-ROOM 159	SLA	2019-05-01	12 VDC	100AH	24 HRS	15 MIN

5. NOTIFICATIONS MADE PRIOR TO TESTING

Monitoring organization	Contact: <u>CAPITOL POLICE</u>	Time: <u>0600</u>
Building management	Contact: <u>HEATH HAUG</u>	Time: <u>0600</u>
Building occupants	Contact: <u>BY HEATH HAUG</u>	Time: <u>0600</u>
Authority having jurisdiction (AHJ)	Contact: <u>NA</u>	Time: <u>NA</u>

Other, if required _____

Contact: NA

Time: NA

6. TESTING RESULTS

6.1 Control Unit and Related Equipment

Description	Visual Inspection or Functional Test	Comments
Control unit	Functional	None
Disconnect switches	Functional	None
Fuses	Functional	None
Ground-fault monitoring	Functional	None
Interface Equipment	Functional	None
Lamps/LEDs/LCDs	Functional	None
Local annunciator	Functional	None
Primary Power	Functional	None
Remote annunciators	Functional	None
Remote power panels	Functional	None
Supervision	Functional	None
Trouble signals	Functional	None

6.2 Secondary Power

Description	Visual Inspection or Functional Test	Comments
Battery condition	Functional, Failed	(2) 100 AH BATTERIES FAILED BY DATE AND LOAD TEST. REPLACEMENT REQUIRED.
Charger test	Functional	SEE NAC PANEL LISTING
Discharge test	Functional, Failed	SEE NAC PANEL LISTING
Load voltage	Functional	SEE NAC PANEL LISTING
Remote panel batteries	Functional	SEE NAC PANEL LISTING

6.3 Notification Appliance Power Extender Panels Secondary Power

ID	Date	Location	Charger Volts	Battery 1 Volts	Battery 2 Volts	Battery 1 Amps	Battery 2 Amps	Pass/Fail
01:01:01:01:NAC-01	2026-01-28	B464	27.73	13.77	13.81	100%	100%	Pass
01:01:01:01:NAC-02	2026-01-27	B382-384	27.55	13.76	13.74	100%	100%	Pass
01:01:01:01:NAC-03	2026-01-27	B382-384	27.37	13.65	13.68	100%	100%	Pass
01:01:01:01:NAC-04	2026-01-27	167U	26.64	13.31	13.32	90%	80%	Pass
01:01:01:01:NAC-05	2026-01-27	167U	26.78	13.56	13.62	100%	100%	Pass
01:01:01:01:NAC-06	2026-01-27	1st Fl. N.E. U1 STAIR ELECTRICAL RM	27.52	13.71	13.75	100%	100%	Pass
01:01:01:01:NAC-07	2026-01-27	267U	27.36	13.67	13.65	100%	100%	Pass
01:01:01:01:NAC-08	2026-01-27	267U	26.68	13.32	13.38	100%	100%	Pass
01:01:01:01:NAC-09	2026-01-27	B174Y	27.35	13.65	13.68	100%	100%	Pass

ID	Date	Location	Charger Volts	Battery 1 Volts	Battery 2 Volts	Battery 1 Amps	Battery 2 Amps	Pass/Fail
01:01:01:01:NAC-10	2026-01-28	B174Y	26.33	13.18	13.19	100%	80%	Pass
01:01:01:01:NAC-11	2026-01-27	367U	27.77	13.76	13.74	100%	100%	Pass
01:01:01:01:NAC-12	2026-01-27	367U (TOP)	27.36	13.72	13.65	100%	100%	Pass
01:01:01:01:NAC-13	2026-01-27	367U (BOTTOM)	27.62	13.69	13.67	100%	100%	Pass
01:01:01:01:NAC-14	2026-01-27	467 (TOP)	27.54	13.64	13.62	100%	100%	Pass
01:01:01:01:NAC-15	2026-01-27	467 (BOTTOM)	26.85	13.42	13.45	100%	100%	Pass
01:01:01:01:NAC-16	2026-01-27	567 (TOP)	27.50	13.65	13.68	100%	100%	Pass
01:01:01:01:NAC-17	2026-01-27	567 (BOTTOM)	26.23	13.12	13.14	80%	80%	Pass
01:01:01:01:NAC-18	2026-01-27	651Y (TOP)	26.64	13.90	11.43	100%	10%	Fail
	Comment:	BATTERIES FAILED LOAD TEST. (2) 8AH BATTERIES REQUIRE REPLACEMENT. TOP CABINET.						
01:01:01:01:NAC-19	2026-01-27	651Y (BOTTOM LEFT)	27.39	13.67	13.67	100%	100%	Pass
01:01:01:01:NAC-20	2026-01-27	651Y (BOTTOM RIGHT)	26.64	13.54	13.64	100%	100%	Pass
01:01:01:01:NAC-21	2026-01-27	751Z	27.54	13.65	13.59	60%	60%	Fail
	Comment:	BATTERIES FAILED LOAD TEST. (2) 8AH BATTERIES REQUIRE REPLACEMENT.						
01:01:01:01:NAC-23	2026-01-27	951Y	26.70	13.36	13.42	100%	100%	Pass
01:01:01:01:T-01	2026-01-27	B271 (LEFT)	27.57	13.77	13.76	100%	100%	Pass
01:01:01:01:T-02	2026-01-27	B271 (CENTER)	27.70	13.91	13.70	100%	90%	Pass
01:01:01:01:T-03	2026-01-27	B271 (RIGHT)	27.70	13.79	13.85	90%	90%	Pass
01:01:01:01:T-04	2026-01-27	751Z	27.63	13.77	13.83	100%	100%	Pass
01:FACP B1-RM. 159	2026-01-28	B1-ROOM 159						Fail
	Comment:	BATTERIES FAILED BY DATE AND LOAD TEST. REPLACEMENT REQUIRED. (2) 100 AH BATTERIES REQUIRE REPLACEMENT.						

6.4 Alarm and Supervisory Alarm Initiating Device

Attach supplementary device test sheets for all initiating devices.

6.5 Notification Appliances

Attach supplementary appliance test sheets for all notification appliances.

6.6 Interface Equipment

Attach supplementary interface component test sheets for all interface components.

6.7 Supervising Station Monitoring

Description	Received	Time	Pass/Fail	Comments
Alarm signal	Yes	2026-01-30	Pass	VERIFIED WITH CAPITOL POLICE
Alarm restoration	Yes	2026-01-30	Pass	VERIFIED WITH CAPITOL POLICE
Trouble signal	Yes	2026-01-30	Pass	VERIFIED WITH CAPITOL POLICE

Trouble restoration	Yes	2026-01-30	Pass	VERIFIED WITH CAPITOL POLICE
Supervisory signal	Yes	2026-01-30	Pass	VERIFIED WITH CAPITOL POLICE
Supervisory restoration	Yes	2026-01-30	Pass	VERIFIED WITH CAPITOL POLICE

7. NOTIFICATIONS THAT TESTING IS COMPLETE

Monitoring organization	Contact: <u>CAPITOL POLICE</u>	Time: <u>1400</u>
Building management	Contact: <u>HEATH HAUG</u>	Time: <u>1400</u>
Building occupants	Contact: <u>BY HEATH HAUG</u>	Time: <u>1400</u>
Authority having jurisdiction (AHJ)	Contact: <u>NA</u>	Time: <u>NA</u>
Other, if required	Contact: <u>NA</u>	Time: <u>NA</u>

8. SYSTEM RESTORED TO NORMAL OPERATION

Date: 2026-01-30 Time: 1300

9. CERTIFICATION

This Testing Was Performed in Accordance with Applicable NFPA72 2022 Standards.

Signed:  Date: 2026-01-30

Printed name: STANLEY LAITINEN, ALEXANDER HANUS Title: Technician License No.: SL #150654, AH #148912

Qualifications (refer to NFPA 72, Section 10.5.3): Inspection, Testing, Service

10. SUMMARY OF EQUIPMENT MARKED AS FAILED WHEN INSPECTED OR TESTED

FACP BATTERIES FAILED BY DATE AND LOAD TEST.(2) 100 AH BATTERIES REQUIRE REPLACEMENT.

HORNSTROBE -2ND FLOOR WEST TOWER SOUTH BEHIND STAIR:

MIKE GOES INTO TROUBLE AND DEACTIVATES AFTER ROUGHLY 20 SECONDS.

Duct Smoke Detectors (P) (Supv)		
Equipment ID	Location	Comment
01:L01-M017	DUCT DET AHU 15 6TH/7TH PH ROOM 738	SCREW IN TERMINAL 3 IS STRIPPED, NOT SEALING CORRECTLY. HOUSING NEEDS REPLACEMENT

NAC Panels			
Equipment ID	Location	Model	Comment
01:01:01:01:NAC-18	651Y (TOP)	FCPS-24	BATTERIES FAILED LOAD TEST. (2) 8AH BATTERIES REQUIRE REPLACEMENT. TOP CABINET.
01:01:01:01:NAC-21	751Z	WHEELOCK/PS-12/24-8	BATTERIES FAILED LOAD TEST. (2) 8AH BATTERIES REQUIRE REPLACEMENT.
01:FACP B1-RM. 159	B1-ROOM 159	NOTIFIER FCI-3030	BATTERIES FAILED BY DATE AND LOAD TEST. REPLACEMENT REQUIRED. (2) 100 AH BATTERIES REQUIRE REPLACEMENT.

11. ACCEPTANCE BY OWNER OR OWNER'S REPRESENTATIVE

The undersigned accepted the test report for the system as specified herein:

Signed:  Date: 2026-01-30

Printed name: HEATH HAUG Email Address: heath.haug@wisconsin.gov

Organization: STATE OF WISCONSIN (30134997) Phone: None

This report will be emailed to the email address provided by the Owner or Owner's Representative and/or sent to the Siemens customer portal for retrieval and viewing by the customer, and retention.

Pursuant to applicable codes and standards, the owner or designated representative is responsible for proper maintenance and care of the system(s) identified in this report. During the site inspection, if Siemens has identified code deficiencies or

impairments, Siemens will recommend certain corrective actions contained in this report. In the event the owner fails to correct such deficiencies or impairments within the required time period per the code, Siemens may be required to report such deficiencies or impairments to the Local AHJ or Fire Marshall per regulatory requirements. Customer shall hold Siemens harmless and releases Siemens of any and all liability due to Customer's failure to correct such deficiencies or impairments.

12. OTHER

12.1 Special Procedures

12.2 Comments

ELEVATOR RECALL TESTED WITH ASSISTANCE FROM ELEVATOR SERVICE PERSON. ELEVATORS RECALLED PROPERLY.

FIRE PHONES NOT TESTED PER CUSTOMER REQUEST.

ALL SMOKE DETECTORS PASSED SENSITIVITY TESTING.
THIS SYSTEM MONITORS THE SENSITIVITY OF THE SMOKE DEVICES AND CAUSES A TROUBLE WHEN OUTSIDE OF ITS LISTED RANGE.

Reviewed the sensitivity of the Analog Smoke/Duct detectors with use of Fire Alarm Control Panel whereby the detector causes signal at the control panel when its sensitivity is outside its listed sensitivity range.
NFPA 72-2016 14.4.3.2-17 (h)(4) states that: (Smoke detector/control unit arrangement whereby the detector causes a signal at the control unit when its sensitivity is outside its listed sensitivity range)

a

NOTIFICATION APPLIANCE SUPPLEMENTARY RECORD OF INSPECTION AND TESTING

1. PROPERTY INFORMATION

Name of property: DEPARTMENT OF HEALTH SERVICES (4433-53703-00035)

Address: 1 WEST WILSON, MADISON WI.

2. NOTIFICATION APPLIANCE TEST RESULTS

2.1 Notification Appliances Equipment Summary by Type

Total Qty	Functionally Tested Qty	Functionally Tested %	Visually Tested Qty	Visually Tested %	Failed Qty	Failed %	Device or System Type
		100%	100%		1		NO DEVICE TYPE SUMMARY LISTING AVAILABLE

2.2 Notification Appliances Testing Results by Type

ALL NOTIFICATION DEVICES PASSED FUNCTIONAL TESTING AND VISUAL INSPECTION WITH THE EXCEPTION OF THE FOLLOWING:

HORNSTROBE -2ND FLOOR WEST TOWER SOUTH BEHIND STAIR:

MIKE GOES INTO TROUBLE AND DEACTIVATES AFTER ROUGHLY 20 SECONDS.

INITIATING DEVICE SUPPLEMENTARY RECORD OF INSPECTION AND TESTING

1. PROPERTY INFORMATION

Name of property: DEPARTMENT OF HEALTH SERVICES (4433-53703-00035)

Address: 1 WEST WILSON, MADISON WI.

2. INITIATING DEVICE TEST RESULTS

2.1 Initiating Devices Equipment Summary by Type

Total Qty	Functionally Tested Qty	Functionally Tested %	Visually Inspected Qty	Visually Inspected %	Failed Qty	Failed %	Device or System Type
3	3	100%	0	0%	0	0%	Duct Smoke Detectors (P)
24	23	95.8%	1	4.2%	1	4.2%	Duct Smoke Detectors (P) (Supv)
77	75	97.4%	2	2.6%	0	0%	Heat Detectors
128	128	100%	0	0%	0	0%	Manual Pull Stations
1	1	100%	0	0%	0	0%	System Smoke Detectors (I)
421	421	100%	0	0%	0	0%	System Smoke Detectors (P)

2.2 Initiating Devices Testing Results by Type

Duct Smoke Detectors (P)					
Row	Date	Dev.#	Location	Visual/Functional	Pass/Fail
1	2026-01-29	01:L05-D080	BASEMENT RM B411 AHU21 DUCT	Functional	Pass
2	2026-01-28	01:L10-D096	DUCT DETECTOR AHU-2 SUPPLY	Functional	Pass
3	2026-01-28	01:L10-D099	DUCT DETECTOR AHU-12 RETURN	Functional	Pass

Duct Smoke Detectors (P) (Supv)					
Row	Date	Dev.#	Location	Visual/Functional	Pass/Fail
1	2026-01-26	01:L01-D060	7TH FL RM 756 AHU-8 DUCT (SUP)	Functional	Pass
	Comment:	NO SAMPLING TUBE			
2	2026-01-26	01:L01-D061	7TH FL RM 756 AHU-8 DUCT (SUP)	Functional	Pass
	Comment:	NO SAMPLING TUBE			
3	2026-01-26	01:L01-M016^1	AHU 7 DUCT DETECTORS SUPPLY	Functional	Pass
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE			
4	2026-01-26	01:L01-M016^2	AHU 7 DUCT DETECTORS RETURN	Functional	Pass
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE			
5	2026-01-26	01:L01-M017	DUCT DET AHU 15 6TH/7TH PH ROOM 738	Visual	Fail
	Comment:	SCREW IN TERMINAL 3 IS STRIPPED,NOT SEALING CORRECTLY. HOUSING NEEDS REPLACEMENT			
6	2026-01-26	01:L01-M032^1	DUCT DET AHU 5 SUPPLY	Functional	Pass
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.			
7	2026-01-26	01:L01-M032^2	DUCT DET AHU 5 RETURN	Functional	Pass
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.			
8	2026-01-26	01:L01-M068^1	8TH FL RM 851U DUCT DET AHU 19 SUPPLY	Functional	Pass
9	2026-01-26	01:L01-M068^2	8TH FL RM 851U DUCT DET AHU 19 RETURN	Functional	Pass

Duct Smoke Detectors (P) (Supv)						
Row	Date	Dev.#	Location	Visual/Functional	Pass/Fail	
10	2026-01-29	01:L02-M046^1	5TH FL. DUCT DET AHU 18 RETURN	Functional	Pass	
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.				
11	2026-01-29	01:L02-M046^2	5TH FL. DUCT DET AHU 18 RETURN	Functional	Pass	
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.				
12	2026-01-26	01:L02-M095^1	5TH FL. RM. 550 DUCT DET AHU 17 SUPPLY	Functional	Pass	
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.				
13	2026-01-26	01:L02-M095^2	5TH FL. RM. 550 DUCT DET AHU 17 RETURN	Functional	Pass	
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.				
14	2026-01-29	01:L02-M096^1	DUCT DET AHU 16 SUPPLY IN 443 U	Functional	Pass	
	Comment:	IN 443 U				
15	2026-01-29	01:L02-M096^2	DUCT DET AHU 16 RETURN IN 443 U	Functional	Pass	
	Comment:	IN 443 U				
16	2026-01-30	01:L06-D080	B1 B137 DUCT DET. (SUP)	Functional	Pass	
	Comment:	ROOM B 135U				
17	2026-01-28	01:L06-M075^1	DUCT DETECTOR AHU 3 SUPPLY	Functional	Pass	
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.				
18	2026-01-28	01:L06-M075^2	DUCT DETECTOR AHU 3 RETURN	Functional	Pass	
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.				
19	2026-01-28	01:L06-M076^1	DUCT DETECTOR AHU 1 SUPPLY	Functional	Pass	
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.				
20	2026-01-28	01:L06-M076^2	DUCT DETECTOR AHU 1 RETURN	Functional	Pass	
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.				
21	2026-01-29	01:L10-M030^1	DUCT DETECTOR AHU 9 SUPPLY	Functional	Pass	
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.				
22	2026-01-29	01:L10-M030^2	DUCT DETECTOR AHU 9 RETURN	Functional	Pass	
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.				
23	2026-01-28	01:L10-M034^1	DUCT DETECTOR AHU 4 SUPPLY	Functional	Pass	
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.				
24	2026-01-28	01:L10-M034^2	DUCT DETECTOR AHU 4 RETURN	Functional	Pass	
	Comment:	2 CONVENTIONAL DETECTORS REPORT TO THIS MODULE.				

Heat Detectors						
Row	Date	Dev.#	Location	Model	Visual/Functional	Pass/Fail
1	2026-01-26	01:L01-D049	7TH FL RM 742X HEAT		Functional	Pass
2	2026-01-28	01:L01-D063	ELEVATOR 6 TOP OF SHAFT HEAT		Functional	Pass
3	2026-01-28	01:L01-D064	ELEVATOR 7 TOP OF SHAFT HEAT		Functional	Pass
4	2026-01-26	01:L02-D005	6TH FL RM 668X HEAT		Functional	Pass
5	2026-01-29	01:L02-D047	5TH FL RM 568X HEAT		Functional	Pass

Heat Detectors						
Row	Date	Dev.#	Location	Model	Visual/ Functional	Pass/ Fail
6	2026-01-26	01:L02-D052	5TH FL CENTER JANITORS CLSOER 546X HEAT		Functional	Pass
7	2026-01-29	01:L02-D077	4TH FL U2 JANITORS CLOSET 446X HEAT		Functional	Pass
8	2026-01-29	01:L02-D084	4TH FL RM 466X HEAT		Functional	Pass
9	2026-01-26	01:L02-D087	6TH FL RM 646X HEAT		Functional	Pass
10	2026-01-30	01:L02-D089	2ND FL RM 246X HEAT		Functional	Pass
	Comment:	ROOM 246W				
11	2026-01-29	01:L02-D090	3RD FL RM 346X HEAT		Functional	Pass
	Comment:	ROOM 346W				
12	2026-01-29	01:L05-D001	B RM B413 HEAT		Functional	Pass
13	2026-01-29	01:L05-D002	B RM B413 HEAT		Functional	Pass
14	2026-01-30	01:L05-D049	2ND FL RM 268X HEAT		Functional	Pass
	Comment:	ROOM 268W				
15	2026-01-29	01:L05-D052	3RD FL RM 374X HEAT		Functional	Pass
	Comment:	ROOM 368				
16	2026-01-29	01:L05-D055	B4 RM B411 HEAT		Functional	Pass
17	2026-01-29	01:L05-D056	B4 RM B415 HEAT		Functional	Pass
18	2026-01-29	01:L05-D057	B4 RM B421 HEAT		Functional	Pass
	Comment:	ROOM 415				
19	2026-01-29	01:L05-D064	B4 RM B413 HEAT		Functional	Pass
20	2026-01-29	01:L05-D066	B4 RM B413 HEAT		Functional	Pass
21	2026-01-30	01:L06-D004	1ST FL RM 168X HEAT		Functional	Pass
	Comment:	ROOM 168W				
22	2026-01-28	01:L06-D047	B3 RM B337 HEAT		Functional	Pass
23	2026-01-28	01:L06-D048	B3 RM B337 HEAT		Functional	Pass
24	2026-01-28	01:L06-D059	B3 RM B325 HEAT		Functional	Pass
25	2026-01-28	01:L06-D061	B3 RM B321 HEAT		Functional	Pass
26	2026-01-28	01:L06-D063	B3 BREAK RM B317 HEAT		Functional	Pass
27	2026-01-29	01:L07-D081	B2 RM B266X HEAT		Functional	Pass
28	2026-01-28	01:L09-D001	ELEVATOR 9 (FREIGHT) EQUIPMENT RM HEAT		Functional	Pass
29	2026-01-28	01:L09-D002	ELEVATOR 9 (FREIGHT) EQUIPMENT RM HEAT		Functional	Pass
30	2026-01-28	01:L09-D004	ELEVATOR 9 (FREIGHT) TOP OF SHAFT HEAT		Functional	Pass
31	2026-01-28	01:L09-D015	ELEVATOR 1 TOP OF SHAFT HEAT		Functional	Pass
32	2026-01-28	01:L09-D017	ELEVATOR 2 TOP OF SHAFT HEAT		Functional	Pass
33	2026-01-26	01:L09-D020	ELEVATOR 6 & 7 EQ. RM HEAT (W. PENTHOUSE) SE		Functional	Pass
34	2026-01-26	01:L09-D021	ELEVATOR 6 & 7 EQ. RM HEAT (W. PENTHOUSE) NE		Functional	Pass
35	2026-01-26	01:L09-D022	ELEVATOR 6 & 7 EQ. RM HEAT (W. PENTHOUSE) S		Functional	Pass
36	2026-01-26	01:L09-D023	ELEVATOR 6 & 7 EQ. RM HEAT (W. PENTHOUSE) N		Functional	Pass
37	2026-01-26	01:L09-D024	ELEVATOR 6 & 7 EQ. RM HEAT (W. PENTHOUSE) SW		Functional	Pass
38	2026-01-26	01:L09-D025	ELEVATOR 6 & 7 EQ. RM HEAT (W. PENTHOUSE) NW		Functional	Pass
39	2026-01-26	01:L09-D026	ELEVATOR 5 EQ. RM HEAT (E. PENTHOUSE) S-7TH FL		Functional	Pass
40	2026-01-26	01:L09-D027	ELEVATOR 5 EQ. RM HEAT (E. PENTHOUSE) N		Functional	Pass
41	2026-01-26	01:L09-D028	C.PENT MACHINE RM P152		Functional	Pass
42	2026-01-26	01:L09-D029	C.PENT MACHINE RM P152		Functional	Pass
43	2026-01-26	01:L09-D030	C.PENT MACHINE RM P152		Functional	Pass
44	2026-01-26	01:L09-D031	C.PENT MACHINE RM P152		Functional	Pass
45	2026-01-26	01:L09-D032	C.PENT MACHINE RM P152		Functional	Pass

Heat Detectors						
Row	Date	Dev.#	Location	Model	Visual/ Functional	Pass/ Fail
46	2026-01-26	01:L09-D033	C.PENT MACHINE RM P152		Functional	Pass
47	2026-01-26	01:L09-D034	C.PENT MACHINE RM P152		Functional	Pass
48	2026-01-26	01:L09-D035	C.PENT MEZZ MACHINE RM P252		Functional	Pass
49	2026-01-26	01:L09-D036	C.PENT MEZZ MACHINE RM P252		Functional	Pass
50	2026-01-30	01:L09-D037	C.PENT MEZZ MACHINE RM P252		Functional	Pass
51	2026-01-26	01:L09-D038	C.PENT MEZZ MACHINE RM P252		Functional	Pass
52	2026-01-26	01:L09-D039	C.PENT MEZZ MACHINE RM P252		Functional	Pass
53	2026-01-26	01:L09-D040	C.PENT MEZZ MACHINE RM P252		Functional	Pass
54	2026-01-26	01:L09-D041	C.PENT MEZZ MACHINE RM P252		Functional	Pass
55	2026-01-26	01:L09-D042	C.PENT MEZZ MACHINE RM P252		Functional	Pass
56	2026-01-26	01:L09-D043	C.PENT MEZZ MACHINE RM P252		Functional	Pass
57	2026-01-26	01:L09-D044	C.PENT MEZZ MACHINE RM P252		Functional	Pass
58	2026-01-26	01:L09-D045	C.PENT MEZZ MACHINE RM P252		Functional	Pass
59	2026-01-26	01:L09-D046	C.PENT MEZZ MACHINE RM P252		Functional	Pass
60	2026-01-26	01:L09-D047	C.PENT MEZZ MACHINE RM P252		Functional	Pass
61	2026-01-26	01:L09-D048	C.PENT MEZZ MACHINE RM P252		Functional	Pass
62	2026-01-30	01:L09-D049	C.PENT MEZZ MACHINE RM P252		Functional	Pass
63	2026-01-26	01:L09-D081	ELEVATOR 6 EQUIP RM UNSAFE HEAT		Functional	Pass
64	2026-01-26	01:L09-D142	E. ELEVATOR 5 EQUIP RM UNSAFE HEAT-7TH FL.		Functional	Pass
65	2026-01-28	01:L09-D153	CENT. ELEVATOR 3 TOP OF SHAFT HEAT		Functional	Pass
66	2026-01-28	01:L09-D154	CENT. ELEVATOR 4 TOP OF SHAFT HEAT		Functional	Pass
67	2026-01-26	01:L09-D156	CENT. ELEVATOR 3 & 4 EQUIP RM HEAT		Functional	Pass
68	2026-01-26	01:L09-D158	CENT. ELEVATOR 3 & 4 EQUIP RM HEAT		Functional	Pass
69	2026-01-29	01:L09-M034	B3 HEAT DET GENERATOR RM B361A	CONVENTIONAL	Visual	Pass
	Comment:	NOT TESTED PER CUSTOMERS REQUEST, NO BYPASS.				
70	2026-01-29	01:L09-M035	B3 HEAT DET GENERATOR RM B361A	CONVENTIONAL	Visual	Pass
	Comment:	NOT TESTED PER CUSTOMERS REQUEST, NO BYPASS.				
71	2026-01-28	01:L10-D011	B3 RM B326 HEAT		Functional	Pass
72	2026-01-28	01:L10-D014	B3 BY RM B313 HEAT		Functional	Pass
73	2026-01-28	01:L10-D040	B3 RM B384 HEAT		Functional	Pass
74	2026-01-28	01:L10-D041	B3 RM B384 HEAT		Functional	Pass
75	2026-01-28	01:L10-D050	B3 RM B361 HEAT		Functional	Pass
76	2026-01-28	01:L10-D055	B3 RM B382 HEAT		Functional	Pass
77	2026-01-28	01:L10-D077	B3 HOUSEKEEPING RM B322 HEAT		Functional	Pass

Manual Pull Stations					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
1	2026-01-26	01:L01-M001	11TH FL SOUTH STAIRWELL PULL	Functional	Pass
2	2026-01-26	01:L01-M003	11TH FL SOUTH STAIRWELL PULL	Functional	Pass
3	2026-01-26	01:L01-M004	11TH FL NORTH STAIRWELL PULL	Functional	Pass
4	2026-01-26	01:L01-M005	10TH FL SOUTH STAIRWELL PULL	Functional	Pass
5	2026-01-26	01:L01-M006	10TH FL SOUTH STAIRWELL PULL	Functional	Pass
6	2026-01-26	01:L01-M007	10TH FL NORTH STAIRWELL PULL	Functional	Pass
7	2026-01-26	01:L01-M008	9TH FL. N SOUTH STAIRWELL PULL	Functional	Pass
8	2026-01-26	01:L01-M009	9TH FL. SOUTH STAIRWELL PULL	Functional	Pass
9	2026-01-26	01:L01-M010	9TH FL. NORTH STAIRWELL PULL	Functional	Pass
10	2026-01-26	01:L01-M011	8TH FL. SOUTH STAIRWELL PULL	Functional	Pass

Manual Pull Stations					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
11	2026-01-26	01:L01-M012	8TH FL. SOUTH STAIRWELL PULL	Functional	Pass
12	2026-01-26	01:L01-M013	8TH FL. NORTH STAIRWELL PULL	Functional	Pass
13	2026-01-26	01:L01-M020	7TH FL. S. WEST STAIRWELL PULL	Functional	Pass
14	2026-01-26	01:L01-M024	7TH FL. N. WEST STAIRWELL PULL	Functional	Pass
15	2026-01-26	01:L01-M025	7TH FL N. CENTRER STAIRWELL PULL	Functional	Pass
16	2026-01-30	01:L01-M026	7TH FL. ELEVATOR LOBBY 1-4 PULL	Functional	Pass
17	2026-01-26	01:L01-M027	7TH FL SOUTH STAIRWELL PULL	Functional	Pass
18	2026-01-26	01:L01-M028	7TH FL SOUTH STAIRWELL PULL	Functional	Pass
19	2026-01-26	01:L01-M070	7TH FL. EAST EXIT TO ROOF PULL	Functional	Pass
20	2026-01-26	01:L02-M005	6TH FL. NORTH STAIRWELL PULL	Functional	Pass
21	2026-01-26	01:L02-M018	6TH FL. S. WEST STAIR PULL	Functional	Pass
22	2026-01-26	01:L02-M019	6TH FL. W ELEV LOBBY PULL	Functional	Pass
23	2026-01-26	01:L02-M020	6TH FL. NORTH CENTER STAIRWELL PULL	Functional	Pass
24	2026-01-26	01:L02-M021	6TH FL . CENTER ELEV LOBBY PULL	Functional	Pass
25	2026-01-26	01:L02-M022	6TH FL. S. CENTER STAIRS PULL	Functional	Pass
26	2026-01-26	01:L02-M023	6TH FL . N. EAST STAIR PULL	Functional	Pass
27	2026-01-26	01:L02-M024	6TH FL BY EAST ELEVATOR PULL	Functional	Pass
28	2026-01-26	01:L02-M025	6TH FL S. EAST STAIR PULL	Functional	Pass
29	2026-01-29	01:L02-M030	5TH FL. S. WEST STAIRWELL PULL	Functional	Pass
30	2026-01-29	01:L02-M031	5TH FL. WEST ELEV. LOBBY PULL	Functional	Pass
31	2026-01-29	01:L02-M032	5TH FL. NORTH WEST STAIRWELL PULL	Functional	Pass
32	2026-01-29	01:L02-M033	5TH FL. N. CENTRAL STAIR PULL	Functional	Pass
33	2026-01-26	01:L02-M034	5TH FL. ELEV. LOBBY PULL	Functional	Pass
34	2026-01-26	01:L02-M035	5TH FL. S. CENTRAL STAIR PULL	Functional	Pass
35	2026-01-26	01:L02-M036	5TH FL. S. CENTRAL STAIR PULL	Functional	Pass
36	2026-01-26	01:L02-M037	5TH FL. EAST ELEV LOBBY PULL	Functional	Pass
37	2026-01-26	01:L02-M038	5TH FL. NORTH EAST STAIR PULL	Functional	Pass
38	2026-01-26	01:L02-M039	5TH FL. SOUTH EAST STAIR PULL	Functional	Pass
39	2026-01-29	01:L02-M060	4TH FL SOUTH WEST STAIRWELL PULL	Functional	Pass
40	2026-01-29	01:L02-M061	4TH FL. BY WEST ELEVATOR PULL	Functional	Pass
41	2026-01-29	01:L02-M062	4TH FL. NORTH WEST STAIR PULL	Functional	Pass
42	2026-01-29	01:L02-M063	4TH FL. NORTH STAIRWELL PULL	Functional	Pass
43	2026-01-29	01:L02-M064	4TH FL. CENTER ELEVATOR LOBBY PULL	Functional	Pass
44	2026-01-29	01:L02-M065	4TH FL. CENTER SOUTH STAIRWELL PULL	Functional	Pass
45	2026-01-29	01:L02-M066	4TH FL. CENTER SOUTH STAIRWELL PULL	Functional	Pass
46	2026-01-29	01:L02-M067	4TH FL. N. EAST STAIR PULL	Functional	Pass
47	2026-01-29	01:L02-M068	4TH FL. EAST ELEV. LOBBY PULL	Functional	Pass
48	2026-01-29	01:L02-M069	4TH FL. S. EAST STAIRWELL PULL	Functional	Pass
49	2026-01-26	01:L02-M097	6TH FL S. CENTRAL STAIR PULL	Functional	Pass
50	2026-01-29	01:L05-M001	3RD FL SOUTH WEST STAIRWELL PULL	Functional	Pass
51	2026-01-29	01:L05-M002	3RD FL . ELEVATOR LOBBY PULL	Functional	Pass
52	2026-01-29	01:L05-M003	3RD FL. NORTH WEST STAIRWELL PULL	Functional	Pass
53	2026-01-29	01:L05-M004	3RD FOOL PULL STATION N. CENTRAL STAIRWELL	Functional	Pass
54	2026-01-29	01:L05-M005	3RD FL. CENTER ELEV LOBBY PULL	Functional	Pass
55	2026-01-29	01:L05-M006	3RD FL. SOUTH CENTRAL STAIR PULL	Functional	Pass
56	2026-01-29	01:L05-M007	3RD FL N. EAST STAIR PULL	Functional	Pass
57	2026-01-29	01:L05-M008	3RD FL. ELEVATOR 5 LOBBY PULL	Functional	Pass
58	2026-01-29	01:L05-M009	3RD FL. S. EAST STAIR PULL	Functional	Pass
59	2026-01-30	01:L05-M031	2ND FL. SOUTH STAIRWELL PULL	Functional	Pass
60	2026-01-30	01:L05-M032	2ND FL. ELEVATOR BY 6-7 PULL	Functional	Pass

Manual Pull Stations					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
61	2026-01-30	01:L05-M034	2ND FL. N. CENTER STAIRWELL PULL	Functional	Pass
62	2026-01-30	01:L05-M036	2ND FL. S. CENTER STAIRWELL PULL	Functional	Pass
63	2026-01-30	01:L05-M037	2ND FL. S. CENTER STAIRWELL PULL	Functional	Pass
64	2026-01-30	01:L05-M038	2ND FL. N. EAST STAIRWELL PULL	Functional	Pass
65	2026-01-30	01:L05-M039	2ND FL. EAST ELEV. LOBBY PULL	Functional	Pass
66	2026-01-30	01:L05-M040	2ND FL. S. EAST STAIRWELL PULL	Functional	Pass
67	2026-01-30	01:L05-M045	2ND FL. BY N WEST STAIRWELL PULL	Functional	Pass
68	2026-01-29	01:L05-M056	B4 BY S WEST EXIT PULL	Functional	Pass
69	2026-01-28	01:L05-M057	3B SOUTH WEST EXIT PULL	Functional	Pass
70	2026-01-29	01:L05-M060	B4 EAST STAIR TELE PULL	Functional	Pass
	Comment:	TIN SHOP B413			
71	2026-01-30	01:L05-M063	2ND FL. ELEVATOR 1-4 LOBBY	Functional	Pass
72	2026-01-30	01:L06-M001	1ST FL. S. WEST STAIRWELL PULL	Functional	Pass
73	2026-01-30	01:L06-M002	1ST FL.. WEST ELEV. LOBBY PULL	Functional	Pass
74	2026-01-30	01:L06-M003	1ST FL. N. WEST STAIRWELL	Functional	Pass
75	2026-01-30	01:L06-M004	1ST FL. N.CENTER STAIRWELL PULL	Functional	Pass
76	2026-01-30	01:L06-M005	1ST FL. CENTER ELEVATOR LOBBY PULL	Functional	Pass
77	2026-01-30	01:L06-M006	1ST FL. N.EAST STAIRWELL PULL	Functional	Pass
78	2026-01-30	01:L06-M007	1ST FL. EAST ELEV. 5 LOBBY PULL	Functional	Pass
79	2026-01-30	01:L06-M008	1ST FL. S.EAST STAIRWELL PULL	Functional	Pass
80	2026-01-30	01:L06-M009	1ST FL. EAST ENTRANCE PULL	Functional	Pass
81	2026-01-30	01:L06-M026	1ST FL. SOUTH CENTER STAIRWELL	Functional	Pass
82	2026-01-30	01:L06-M027	1ST FL. SOUTH CENTER STAIRWELL	Functional	Pass
83	2026-01-27	01:L06-M028	B1 RM B174 S.WEST STAIRWELL PULL	Functional	Pass
84	2026-01-30	01:L06-M029	B1 N.WEST ENTRANCE	Functional	Pass
85	2026-01-27	01:L06-M030	B1 NORTH WEST STAIRWELL PULL	Functional	Pass
86	2026-01-27	01:L06-M031	B1 N.CENTER STAIRWELL PULL	Functional	Pass
87	2026-01-27	01:L06-M032	B1 CENTER ELEV 1-4 LOBBY PULL	Functional	Pass
88	2026-01-27	01:L06-M033	B1 CENTER TOWER S.CENTER STAIRWELL PULL	Functional	Pass
89	2026-01-27	01:L06-M034	B1 CENTER TOWER S.CENTER STAIRWELL PULL	Functional	Pass
90	2026-01-27	01:L06-M035	B1 N.EAST STAIRWELL PULL	Functional	Pass
91	2026-01-27	01:L06-M040	B1 EAST ELEV. 5 LOBBY	Functional	Pass
92	2026-01-27	01:L06-M041	B1 E.TOWER S.EAST STAIRWELL PULL	Functional	Pass
93	2026-01-28	01:L06-M060	B3 N.EAST STAIR PULL	Functional	Pass
94	2026-01-28	01:L06-M062	B3 EAST ELEV. LOBBY PULL	Functional	Pass
95	2026-01-28	01:L06-M065	B3 ROOM B333 PULL	Functional	Pass
96	2026-01-28	01:L06-M066	B3 ROOM B331 PULL	Functional	Pass
97	2026-01-28	01:L06-M069	B3 ROOM B327 PULL	Functional	Pass
98	2026-01-28	01:L06-M070	B3 RM B332 PULL	Functional	Pass
99	2026-01-28	01:L06-M072	B3 S.EAST STAIR PULL	Functional	Pass
100	2026-01-28	01:L06-M077	B3 RM B334 PULL	Functional	Pass
101	2026-01-30	01:L06-M079	1ST FL. NORTH EAST EXIT PULL	Functional	Pass
102	2026-01-27	01:L06-M093	B1 ELEVATOR 6 & 7 LOBBY PULL	Functional	Pass
103	2026-01-30	01:L06-M095	1ST FL. MAIN ENTRANCE PULL	Functional	Pass
104	2026-01-29	01:L07-M001	B2 S.EAST STAIR PULL	Functional	Pass
105	2026-01-29	01:L07-M004	B2 S.EAST STAIR PULL	Functional	Pass
106	2026-01-29	01:L07-M006	B2 RM. B244 EXIT PULL	Functional	Pass
107	2026-01-29	01:L07-M007	B2 EXIT BY ELEV 5 LOBBY PULL	Functional	Pass
108	2026-01-29	01:L07-M010	B2 EAST ELEV. 5 LOBBY PULL	Functional	Pass
109	2026-01-29	01:L07-M011	B2 N. EAST STAIR PULL	Functional	Pass

Manual Pull Stations					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
110	2026-01-29	01:L07-M014	B2 ELEVATOR LOBBY PULL	Functional	Pass
111	2026-01-29	01:L07-M015	B2 S.CENTER EXIT PULL	Functional	Pass
112	2026-01-29	01:L07-M018	B2 CAFE S. STAIRWELL PULL	Functional	Pass
113	2026-01-29	01:L07-M021	B2 CAFETERIA EXIT PULL	Functional	Pass
114	2026-01-29	01:L07-M022	B2 EXIT TO PATIO	Functional	Pass
115	2026-01-29	01:L07-M025	B2 N.W. IN STAIRWELL EXIT TO PATIO	Visual	Pass
	Comment:	PANEL DOES NOT HAVE LOCATION DESCRIPTION. THIS SHOULD BE PROGRAMMED SO THE LOCATION SHOWS ON THE PANEL IN THE EVENT OF AN ACTUAL FIRE.			
116	2026-01-29	01:L07-M026	B2 WEST ELEV 6-7 LOBBY PULL	Functional	Pass
117	2026-01-29	01:L07-M029	B2 WEST HALL PULL	Functional	Pass
118	2026-01-29	01:L07-M031	B2 S.WEST ENTRANCE PULL	Functional	Pass
119	2026-01-29	01:L07-M032	B2 LOADING DOCK EXIT PULL	Functional	Pass
120	2026-01-29	01:L07-M034	B2 N.CENTER STAIRWELL PULL	Functional	Pass
121	2026-01-29	01:L07-M036	B2 N. WEST STAIRWELL PULL	Functional	Pass
122	2026-01-27	01:L09-M070	B1 PULL STATION FIRE COMMAND CENTER ROOM B159	Functional	Pass
123	2026-01-28	01:L10-M003	B3 N.WEST STAIRWELL PULL	Functional	Pass
124	2026-01-28	01:L10-M005	B3 N.CEN. STAIR PULL	Functional	Pass
125	2026-01-28	01:L10-M007	B3 CENTER ELEV. LOBBY PULL	Functional	Pass
126	2026-01-28	01:L10-M009	B3 WEST ELEV. LOBBY 6-7 PULL	Functional	Pass
127	2026-01-29	01:L10-M015	B3 S.CENTER STAIR PULL	Functional	Pass
128	2026-01-29	01:L10-M016	B3 MECH RM BY S. STAIR PULL	Functional	Pass

System Smoke Detectors (I)					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
1	2026-01-28	01:L06-D049	B3 RM B333 UNDER FLOOR (ION)	Functional	Pass

System Smoke Detectors (P)					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
1	2026-01-26	01:L01-D001	11TH FL RM 1150 S. STAIRWELL	Functional	Pass
2	2026-01-26	01:L01-D002	11TH FL RM 1150 DATA CLOSET	Functional	Pass
3	2026-01-26	01:L01-D003	11TH FL ELEVATOR LOBBY SMOKE	Functional	Pass
4	2026-01-26	01:L01-D004	11TH FL ELEVATOR LOBBY SMOKE	Functional	Pass
5	2026-01-26	01:L01-D005	11TH FL RM 1151 ELECTRICAL CLOSET	Functional	Pass
6	2026-01-26	01:L01-D006	11TH FL RM 1151 ELECTRICAL CLOSET	Functional	Pass
7	2026-01-26	01:L01-D007	10TH FL RM 1050 ELECTRICAL CLOSET	Functional	Pass
8	2026-01-26	01:L01-D008	10TH FL RM 1050 DATA CLOSET	Functional	Pass
9	2026-01-26	01:L01-D009	10TH FL ELEVATOR 3 & 4 LOBBY SMOKE	Functional	Pass
10	2026-01-26	01:L01-D010	10TH FL ELEVATOR 1 & 2 LOBBY SMOKE	Functional	Pass
11	2026-01-26	01:L01-D011	10TH FL RM 1055X SMOKE	Functional	Pass
	Comment:	ROOM 1047Y INSIDE 1055X			
12	2026-01-26	01:L01-D012	10TH FL RM 1051 DATA CLOSET	Functional	Pass
13	2026-01-26	01:L01-D013	10TH FL RM 1051 ELECTRICAL CLOSET	Functional	Pass
14	2026-01-26	01:L01-D014	9TH FL RM 950 ELECTRICAL CLOSET	Functional	Pass
15	2026-01-26	01:L01-D015	9TH FL RM 950 DATA CLOSET	Functional	Pass
16	2026-01-26	01:L01-D016	9TH FL ELEVATOR 3 & 4 LOBBY SMOKE	Functional	Pass
17	2026-01-26	01:L01-D017	9TH FL ELEVATOR 1 & 2 LOBBY SMOKE	Functional	Pass
18	2026-01-26	01:L01-D018	9TH FL RM 955X SMOKE	Functional	Pass
	Comment:	RM 947 Y INSIDE JANITORS CLOSET			
19	2026-01-26	01:L01-D019	9TH FL RM 951 DATA CLOSET	Functional	Pass

System Smoke Detectors (P)					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
20	2026-01-26	01:L01-D020	9TH FL RM 951 ELECTRICAL CLOSET	Functional	Pass
21	2026-01-26	01:L01-D021	8TH FL RM 850 ELECTRICAL CLOSET	Functional	Pass
22	2026-01-26	01:L01-D023	8TH FL RM 850 ELECTRICAL CLOSET	Functional	Pass
	Comment:	DATA ROOM			
23	2026-01-26	01:L01-D024	8TH FL ELEVATOR 3 & 4 LOBBY SMOKE	Functional	Pass
24	2026-01-26	01:L01-D025	8TH FL ELEVATOR 1 & 2 LOBBY SMOKE	Functional	Pass
25	2026-01-26	01:L01-D026	8TH FL RM 855X SMOKE	Functional	Pass
	Comment:	IN JANOTORS CLOSET 855W			
26	2026-01-26	01:L01-D027	8TH FL MECHANICAL RM 851	Functional	Pass
27	2026-01-26	01:L01-D028	8TH FL MECHANICAL RM 851	Functional	Pass
28	2026-01-26	01:L01-D029	8TH FL RM 851L DATA CLOSET	Functional	Pass
29	2026-01-26	01:L01-D030	8TH FL RM 851L ELECTRICAL CLOSET	Functional	Pass
30	2026-01-26	01:L01-D031	8TH FL LOBBY BY 851	Functional	Pass
31	2026-01-26	01:L01-D032	PENTHOUSE ELEVATOR 6 & 7	Functional	Pass
32	2026-01-26	01:L01-D033	PENTHOUSE ELEVATOR 6 & 7	Functional	Pass
33	2026-01-26	01:L01-D034	6TH FL ELEVATOR 5 EQUIPMENT RM-7TH FL	Functional	Pass
34	2026-01-26	01:L01-D035	6TH FL PENTHOUSE AHU-7 ON 7TH FL	Functional	Pass
35	2026-01-30	01:L01-D036	7TH FL 756 BACK STAIRWELL	Functional	Pass
36	2026-01-26	01:L01-D037	7TH FL MECH RM 756 AHU-8	Functional	Pass
37	2026-01-26	01:L01-D038	7TH FL RM 756 ELECTRICAL CLOSET AHU-8	Functional	Pass
	Comment:	DATA CLOSET			
38	2026-01-28	01:L01-D039	TOP OF SHAFT ELEVATORS 6 & 7	Functional	Pass
39	2026-01-26	01:L01-D040	7TH FL RM 756 FRT STAIRWELL	Functional	Pass
40	2026-01-26	01:L01-D041	7TH FL RM 751 ELECTRICAL CLOSET	Functional	Pass
41	2026-01-26	01:L01-D042	7TH FL RM 751 DATA CLOSET	Functional	Pass
42	2026-01-26	01:L01-D043	7TH FL LOBBY BY 756	Functional	Pass
43	2026-01-26	01:L01-D044	7TH FL ELEVATOR LOBBY	Functional	Pass
44	2026-01-26	01:L01-D045	7TH FL ELEVATOR LOBBY	Functional	Pass
45	2026-01-26	01:L01-D046	7TH FL ELEVATOR LOBBY BY 751	Functional	Pass
46	2026-01-26	01:L01-D047	7TH FL RM 747Z SMOKE	Functional	Pass
47	2026-01-26	01:L01-D048	7TH FL OUTSIDE RM 736	Functional	Pass
48	2026-01-26	01:L01-D050	7TH FL RM 750 ELECTRICAL CLOSET	Functional	Pass
49	2026-01-28	01:L01-D052	TOP OF SHAFT ELEVATOR 5	Functional	Pass
50	2026-01-26	01:L01-D053	6TH FL UNIT 1 FRONT STAIR SMOKE-7TH FL	Functional	Pass
	Comment:	IN P.H. TO ELEVATOR 5			
51	2026-01-26	01:L01-D054	6TH FL HALLWAY BY AHU-15	Functional	Pass
52	2026-01-26	01:L01-D055	6TH FL MECH RM PENT AHU-15-7TH FL	Functional	Pass
53	2026-01-26	01:L01-D056	6TH MECH RM PENT AHU-15-7TH FL	Functional	Pass
54	2026-01-30	01:L01-D057	6TH UNIT 1 PENT SMOKE	Functional	Pass
55	2026-01-26	01:L01-D058	11TH FL UN 2 PENT AHU-5	Functional	Pass
56	2026-01-26	01:L01-D059	11TH FL UN 2 PENT AHU-5	Functional	Pass
57	2026-01-26	01:L01-D075	7TH FL RM 750 DATA CLOSET	Functional	Pass
58	2026-01-26	01:L01-D080	11TH FL LOBBY STAIRS	Functional	Pass
59	2026-01-26	01:L02-D001	6TH FL RM 672 ELECTRICAL CLOSET	Functional	Pass
60	2026-01-26	01:L02-D002	6TH FL RM 672 ELECTRICAL CLOSET	Functional	Pass
61	2026-01-26	01:L02-D003	6TH FL ELEVATOR 6 & 7 LOBBY	Functional	Pass
62	2026-01-26	01:L02-D004	6TH FL WEST HALL OUTSIDE 665	Functional	Pass
63	2026-01-26	01:L02-D006	6TH FL RM 666Y SMOKE	Functional	Pass
64	2026-01-26	01:L02-D007	6TH FL OUTSIDE RM 662X	Functional	Pass
65	2026-01-26	01:L02-D008	6TH FL OUTSIDE RM 656	Functional	Pass

System Smoke Detectors (P)					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
66	2026-01-26	01:L02-D009	6TH FL 651 ELECTRICAL CLOSET	Functional	Pass
67	2026-01-26	01:L02-D010	6TH FL 651 ELECTRICAL CLOSET-DATA	Functional	Pass
68	2026-01-26	01:L02-D011	6TH FL N. STAIRWELL BY 656	Functional	Pass
69	2026-01-26	01:L02-D012	6TH FL BY ELEVATOR 1 & 2	Functional	Pass
70	2026-01-26	01:L02-D013	6TH FL BY ELEVATOR 3 & 4	Functional	Pass
71	2026-01-26	01:L02-D014	6TH FL OUTSIDE RM 651	Functional	Pass
72	2026-01-26	01:L02-D015	6TH FL OUTSIDE RM 643	Functional	Pass
73	2026-01-26	01:L02-D016	6TH FL OUTSIDE RM 639	Functional	Pass
74	2026-01-26	01:L02-D017	6TH FL OUTSIDE RM 630	Functional	Pass
75	2026-01-26	01:L02-D018	6TH FL OUTSIDE RM 627	Functional	Pass
76	2026-01-26	01:L02-D019	6TH FL ELEVATOR SMOKE BY 618	Functional	Pass
77	2026-01-26	01:L02-D020	6TH FL UNIT 1 FRONT STR DATA RM SMOKE	Functional	Pass
78	2026-01-26	01:L02-D021	6TH FL UNIT 1 FRONT STR ELECTRICAL RM SMOKE	Functional	Pass
79	2026-01-26	01:L02-D022	6TH FL RM 650 BACK STR ELECTRICAL RM SMOKE	Functional	Pass
80	2026-01-26	01:L02-D023	6TH FL RM 618 TOP OF STAIRS SMOKE	Functional	Pass
81	2026-01-29	01:L02-D026	5TH FL MECH RM 572 AHU-18	Functional	Pass
82	2026-01-29	01:L02-D027	5TH FL MECH RM 572 AHU-18	Functional	Pass
83	2026-01-29	01:L02-D028	5TH FL ELEVATOR 6 & 7 LOBBY SMOKE	Functional	Pass
84	2026-01-29	01:L02-D029	5TH FL RM 572 AHU-18 DATA CLOSET	Functional	Pass
85	2026-01-29	01:L02-D030	5TH FL RM 572 AHU-18 ELECTRICAL CLOSET	Functional	Pass
86	2026-01-29	01:L02-D031	5TH FL OUTSIDE RM 565	Functional	Pass
87	2026-01-29	01:L02-D032	5TH FL OUTSIDE RM 561	Functional	Pass
88	2026-01-29	01:L02-D033	5TH FL OUTSIDE RM 558	Functional	Pass
89	2026-01-29	01:L02-D034	5TH FL HALL BY 551	Functional	Pass
90	2026-01-26	01:L02-D035	5TH FL UN2 ELEVATOR LOBBY SMOKE	Functional	Pass
91	2026-01-26	01:L02-D036	5TH FL BY RM 543 SMOKE	Functional	Pass
92	2026-01-26	01:L02-D037	5TH FL OUTSIDE RM 534 SMOKE	Functional	Pass
93	2026-01-26	01:L02-D038	5TH FL BY RM 531 SMOKE	Functional	Pass
94	2026-01-26	01:L02-D039	5TH FL BY RM 527 SMOKE	Functional	Pass
95	2026-01-26	01:L02-D040	5TH FL ELEVATOR 5 HALL SMOKE	Functional	Pass
96	2026-01-26	01:L02-D041	5TH FL ELEVATOR 1 & 2 LOBBY SMOKE	Functional	Pass
97	2026-01-26	01:L02-D042	5TH FL ELEVATOR 3 & 4 LOBBY SMOKE	Functional	Pass
98	2026-01-26	01:L02-D043	5TH FL MECH RM 550 AHU-17	Functional	Pass
99	2026-01-26	01:L02-D044	5TH FL MECH RM 550 AHU-17	Functional	Pass
100	2026-01-26	01:L02-D045	5TH FL RM 550 ELECTRICAL CLOSET	Functional	Pass
101	2026-01-26	01:L02-D046	5TH FL RM 547Z SMOKE	Functional	Pass
102	2026-01-29	01:L02-D048	5TH FL RM 566Y SMOKE	Functional	Pass
103	2026-01-29	01:L02-D049	5TH FL RM 551 SMOKE	Functional	Pass
104	2026-01-29	01:L02-D050	5TH FL RM 551 DATA	Functional	Pass
105	2026-01-26	01:L02-D051	5TH FL RM AHU-17 ELECTRICAL CLOSET-DATA	Functional	Pass
106	2026-01-26	01:L02-D053	5TH FL U1 ELECTRICAL RM FRNT STRS	Functional	Pass
107	2026-01-26	01:L02-D054	5TH FL U1 DATA RM FRNT STRS	Functional	Pass
108	2026-01-29	01:L02-D060	4TH FL RM 472 ELECTRICAL CLOSET	Functional	Pass
	Comment:	DATA			
109	2026-01-29	01:L02-D061	4TH FL RM 462 ELECTRICAL CLOSET	Functional	Pass
	Comment:	IN RM. 472			
110	2026-01-29	01:L02-D062	4TH FL ELEVATOR 6 & 7 HALL SMOKE	Functional	Pass
111	2026-01-29	01:L02-D063	4TH FL OUTSIDE RM 465 SMOKE	Functional	Pass
112	2026-01-29	01:L02-D064	4TH FL OUTSIDE RM 462X SMOKE	Functional	Pass
113	2026-01-29	01:L02-D065	4TH FL BY RM 456 SMOKE	Functional	Pass

System Smoke Detectors (P)					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
114	2026-01-29	01:L02-D066	4TH FL U2 FRNT STRS BY 451 SMOKE	Functional	Pass
115	2026-01-29	01:L02-D067	4TH FL BY RM 451 SMOKE	Functional	Pass
116	2026-01-29	01:L02-D068	4TH FL ELEVATOR 1 & 2 LOBBY SMOKE	Functional	Pass
117	2026-01-29	01:L02-D069	4TH FL ELEVATOR 3 & 4 LOBBY SMOKE	Functional	Pass
118	2026-01-29	01:L02-D070	4TH FL BY RM 442X SMOKE	Functional	Pass
119	2026-01-29	01:L02-D071	4TH FL BY RM 434 SMOKE	Functional	Pass
120	2026-01-29	01:L02-D072	4TH FL OUTSIDE RM 430 SMOKE	Functional	Pass
121	2026-01-29	01:L02-D073	4TH FL BY RM 433 SMOKE	Functional	Pass
122	2026-01-29	01:L02-D074	4TH FL ELEVATOR 5 LOBBY SMOKE	Functional	Pass
123	2026-01-29	01:L02-D075	4TH FL U1 DATA RM FRNT STRS SMOKE	Functional	Pass
124	2026-01-29	01:L02-D076	4TH FL U1 ELECTRICAL RM FRNT STRS SMOKE	Functional	Pass
125	2026-01-29	01:L02-D078	4TH FL RM 447Y SMOKE	Functional	Pass
126	2026-01-29	01:L02-D079	4TH FL AHU-16 MECH RM 443 U	Functional	Pass
127	2026-01-29	01:L02-D080	4TH FL RM 451 DATA RM SMOKE	Functional	Pass
128	2026-01-29	01:L02-D081	4TH FL RM 451 ELECTRICAL RM SMOKE	Functional	Pass
129	2026-01-29	01:L02-D082	4TH FL RM 450 ELECTRICAL RM SMOKE	Functional	Pass
130	2026-01-29	01:L02-D083	4TH FL RM 450 DATA RM SMOKE	Functional	Pass
131	2026-01-29	01:L02-D085	4TH FL RM 466Y SMOKE	Functional	Pass
132	2026-01-26	01:L02-D086	6TH FL RM 647Z SMOKE	Functional	Pass
133	2026-01-26	01:L02-D088	6TH FL RM 650 DATA CLOSET SMOKE	Functional	Pass
134	2026-01-29	01:L05-D003	3RD FL OUTSIDE RM 366X SMOKE	Functional	Pass
135	2026-01-29	01:L05-D004	3RD FL OUTSIDE RM 358 SMOKE	Functional	Pass
136	2026-01-29	01:L05-D005	3RD FL U2 FRNT STRS SMOKE	Functional	Pass
137	2026-01-29	01:L05-D006	3RD FL ELEVATOR 1 & 2 LOBBY	Functional	Pass
138	2026-01-29	01:L05-D007	3RD FL ELEVATOR 3 & 4 LOBBY	Functional	Pass
139	2026-01-29	01:L05-D008	3RD FL ELEVATOR LOBBY BY RM 351	Functional	Pass
140	2026-01-29	01:L05-D009	3RD FL OUTSIDE RM 342X SMOKE	Functional	Pass
141	2026-01-29	01:L05-D010	3RD FL OUTSIDE RM 343 SMOKE	Functional	Pass
142	2026-01-29	01:L05-D011	3RD FL OUTSIDE RM 330 SMOKE	Functional	Pass
143	2026-01-29	01:L05-D012	3RD FL OUTSIDE RM 335 SMOKE	Functional	Pass
144	2026-01-29	01:L05-D013	3RD FL ELEVATOR 5 LOBBY SMOKE	Functional	Pass
145	2026-01-29	01:L05-D014	3RD FL RM 372 ELECTRICAL CLOSET	Functional	Pass
146	2026-01-29	01:L05-D015	3RD FL RM 372 DATA CLOSET	Functional	Pass
147	2026-01-29	01:L05-D016	3RD FL RM 351 ELECTRICAL CLOSET	Functional	Pass
148	2026-01-29	01:L05-D017	3RD FL RM 351 DATA CLOSET	Functional	Pass
149	2026-01-29	01:L05-D018	3RD FL RM 350 ELECTRICAL CLOSET	Functional	Pass
150	2026-01-29	01:L05-D019	3RD FL RM 350 DATA CLOSET	Functional	Pass
151	2026-01-29	01:L05-D020	3RD FL RM 347Z SMOKE	Functional	Pass
	Comment:	ROOM 347Y			
152	2026-01-29	01:L05-D021	3RD FL U1 ELECTRICAL RM FRNT STRS SMOKE	Functional	Pass
153	2026-01-29	01:L05-D022	3RD FL U1 DATA RM FRNT STRS SMOKE	Functional	Pass
154	2026-01-30	01:L05-D026	2ND FL RM 272 DATA CLOSET	Functional	Pass
155	2026-01-30	01:L05-D027	2ND FL RM 272 ELECTRICAL CLOSET	Functional	Pass
156	2026-01-30	01:L05-D028	2ND FL BY RM 265 SMOKE	Functional	Pass
157	2026-01-30	01:L05-D030	2ND FL BY RM 261 SMOKE	Functional	Pass
158	2026-01-30	01:L05-D031	2ND FL BY RM 256 SMOKE	Functional	Pass
159	2026-01-30	01:L05-D032	2ND FL OUTSIDE RM 253 SMOKE	Functional	Pass
160	2026-01-30	01:L05-D033	2ND FL ELEVATOR 1 & 2 LOBBY SMOKE	Functional	Pass
161	2026-01-30	01:L05-D034	2ND FL ELEVATOR 3 & 4 LOBBY SMOKE	Functional	Pass
162	2026-01-30	01:L05-D035	2ND FL ELEVATOR LOBBY BY 247Z	Functional	Pass

System Smoke Detectors (P)					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
163	2026-01-30	01:L05-D036	2ND FL OUTSIDE RM 242X SMOKE	Functional	Pass
164	2026-01-30	01:L05-D037	2ND FL OUTSIDE RM 243 SMOKE	Functional	Pass
165	2026-01-30	01:L05-D038	2ND FL OUTSIDE RM 237 SMOKE	Functional	Pass
166	2026-01-30	01:L05-D039	2ND FL OUTSIDE RM 233 SMOKE	Functional	Pass
167	2026-01-30	01:L05-D040	2ND FL ELEVATOR 5 LOBBY SMOKE	Functional	Pass
168	2026-01-30	01:L05-D041	2ND FL U1 DATA RM FRNT STRS SMOKE	Functional	Pass
169	2026-01-30	01:L05-D042	2ND FL U1 ELECTRICAL RM FRNT STRS SMOKE	Functional	Pass
170	2026-01-30	01:L05-D043	2ND FL RM 247Z SMOKE	Functional	Pass
	Comment:	ROOM 247Y			
171	2026-01-30	01:L05-D044	2ND FL RM 250 DATA CLOSET SMOKE	Functional	Pass
172	2026-01-30	01:L05-D045	2ND FL RM 253 DATA CLOSET SMOKE	Functional	Pass
173	2026-01-30	01:L05-D046	2ND FL RM 253 ELECTRICAL CLOSET SMOKE	Functional	Pass
174	2026-01-30	01:L05-D047	2ND FL RM 250 ELECTRICAL CLOSET SMOKE	Functional	Pass
175	2026-01-30	01:L05-D048	2ND FL RM 266Y SMOKE	Functional	Pass
176	2026-01-30	01:L05-D050	2ND FL ELEVATOR 6 & 7 LOBBY	Functional	Pass
177	2026-01-29	01:L05-D051	3RD FL RM 370Y SMOKE	Functional	Pass
	Comment:	ROOM 366Y			
178	2026-01-29	01:L05-D058	B4 OUTSIDE RM B413 SMOKE	Functional	Pass
179	2026-01-29	01:L05-D059	B4 ELEVATOR 9 LOBBY B4 SMOKE	Functional	Pass
180	2026-01-29	01:L05-D060	B4 HALLWAY BY RM B421 SMOKE	Functional	Pass
181	2026-01-29	01:L05-D061	B4 HALLWAY BY RM B421 SMOKE	Functional	Pass
182	2026-01-29	01:L05-D062	B4 HALLWAY BY RM B421 SMOKE	Functional	Pass
183	2026-01-29	01:L05-D063	B4 HALLWAY BY RM B421 SMOKE	Functional	Pass
184	2026-01-29	01:L05-D067	B4 OUTSIDE RM B427 SMOKE	Functional	Pass
185	2026-01-29	01:L05-D068	B4 HALLWAY BY RM B464 SMOKE	Functional	Pass
186	2026-01-29	01:L05-D069	B4 HALLWAY BY RM B464 SMOKE	Functional	Pass
187	2026-01-29	01:L05-D070	B4 HALLWAY BY RM B464 SMOKE	Functional	Pass
188	2026-01-29	01:L05-D071	B4 RM B464 SMOKE	Functional	Pass
189	2026-01-29	01:L05-D072	B4 RM B464 SMOKE	Functional	Pass
190	2026-01-29	01:L05-D073	3RD FL ELEVATOR 6 & 7 LOBBY SMOKE	Functional	Pass
191	2026-01-29	01:L05-D074	3RD FL BY RM 365 SMOKE	Functional	Pass
192	2026-01-29	01:L05-D075	3RD FL. NEAR EAST ELEVATOR	Functional	Pass
193	2026-01-30	01:L06-D001	1ST FL RM 172 ELECTRICAL CLOSET SMOKE	Functional	Pass
	Comment:	DATA ROOM			
194	2026-01-30	01:L06-D002	1ST FL RM 172 ELECTRIC CLOSET SMOKE	Functional	Pass
195	2026-01-30	01:L06-D003	1ST FL ELEVATOR 6 & 7 LOBBY SMOKE	Functional	Pass
196	2026-01-28	01:L06-D006	1ST FL ELEVATOR 1 & 2 LOBBY SMOKE	Functional	Pass
197	2026-01-30	01:L06-D007	1ST FL ELEVATOR 3 & 4 LOBBY SMOKE	Functional	Pass
198	2026-01-30	01:L06-D008	1ST FL RM 150 ELECTRICAL CLOSET SMOKE	Functional	Pass
199	2026-01-30	01:L06-D009	1ST FL RM 150 ELECTRICAL CLOSET SMOKE	Functional	Pass
	Comment:	DATA ROOM			
200	2026-01-30	01:L06-D010	1ST FL HALLWAY BY 133	Functional	Pass
201	2026-01-30	01:L06-D011	1ST FL HALLWAY BY 131	Functional	Pass
202	2026-01-28	01:L06-D012	1ST FL ELEVATOR 5 LOBBY SMOKE	Functional	Pass
203	2026-01-30	01:L06-D013	1ST FL U1 HAN-CAP	Functional	Pass
204	2026-01-30	01:L06-D014	1ST FL U1 RM IN STAIRS	Functional	Pass
205	2026-01-30	01:L06-D015	1ST FL U1 RM IN STAIRS	Functional	Pass
	Comment:	DATA ROOM			
206	2026-01-30	01:L06-D016	1ST FL RM 147Z SMOKE	Functional	Pass
207	2026-01-30	01:L06-D017	1ST FL RM 153Y SMOKE	Functional	Pass

System Smoke Detectors (P)					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
	Comment:	ROOM 154Z			
208	2026-01-27	01:L06-D018	B RM B174 ELECTRICAL CLOSET	Functional	Pass
209	2026-01-27	01:L06-D019	B RM B174 ELECTRICAL CLOSET	Functional	Pass
210	2026-01-27	01:L06-D020	B ELEVATOR 6 & 7 LOBBY SMOKE	Functional	Pass
211	2026-01-27	01:L06-D021	N. WEST ENTRANCE SMOKE	Functional	Pass
212	2026-01-27	01:L06-D022	B OUTSIDE RM B159	Functional	Pass
213	2026-01-27	01:L06-D023	B OUTSIDE RM B160	Functional	Pass
214	2026-01-27	01:L06-D024	B OUTSIDE RM B156	Functional	Pass
215	2026-01-27	01:L06-D025	B UNIT 2 HALL BY RM B155	Functional	Pass
216	2026-01-27	01:L06-D026	1B ELEVATOR 1 & 2 1B U2	Functional	Pass
217	2026-01-27	01:L06-D027	1B ELEVATOR 3 & 4 1B U2	Functional	Pass
218	2026-01-27	01:L06-D028	B1 RM. B150 SMOKE	Functional	Pass
219	2026-01-27	01:L06-D029	B1 OUTSIDE RM B147Z SMOKE	Functional	Pass
	Comment:	OUTSIDE ROOM B147Y			
220	2026-01-27	01:L06-D030	B1 OUTSIDE RM B141 SMOKE	Functional	Pass
221	2026-01-27	01:L06-D031	B1 OUTSIDE RM B139 SMOKE	Functional	Pass
222	2026-01-27	01:L06-D032	B1 OUTSIDE RM B133 SMOKE	Functional	Pass
223	2026-01-27	01:L06-D033	B1 RM B137 MECH RM SMOKE	Functional	Pass
	Comment:	ROOM B 135U			
224	2026-01-27	01:L06-D034	B1 RM B137 MECH RM SMOKE	Functional	Pass
	Comment:	ROOM B 135U			
225	2026-01-27	01:L06-D035	B1 RM B137 MECH RM SMOKE	Functional	Pass
	Comment:	ROOM B 135U			
226	2026-01-27	01:L06-D036	B1 U1 FRNT STR B1 CLOSET	Functional	Pass
227	2026-01-27	01:L06-D037	B1 OUTSIDE U1 STR B1 FT	Functional	Pass
	Comment:	OUTSIDE B124			
228	2026-01-27	01:L06-D038	B1 RM IN STAIRS U1 CLOSET	Functional	Pass
229	2026-01-27	01:L06-D039	B1 ELEVATOR 5 LOBBY SMOKE	Functional	Pass
230	2026-01-27	01:L06-D040	B1 WOMENS RESTROOM B124A	Functional	Pass
231	2026-01-27	01:L06-D041	B1 B150 ELECTRICAL CLOSET	Functional	Pass
232	2026-01-27	01:L06-D042	B1 RM B166Y SMOKE	Functional	Pass
233	2026-01-27	01:L06-D043	B1 RM B168X SMOKE	Functional	Pass
234	2026-01-27	01:L06-D044	B1 RM B147Z SMOKE	Functional	Pass
	Comment:	ROOM B147Y			
235	2026-01-28	01:L06-D045	B3 RM B340 SMOKE	Functional	Pass
236	2026-01-28	01:L06-D046	B3 RM B340 SMOKE	Functional	Pass
237	2026-01-28	01:L06-D050	B3 RM B333 SMOKE	Functional	Pass
238	2026-01-28	01:L06-D051	B3 RM B338 SMOKE ELECTRIC ROOM	Functional	Pass
239	2026-01-29	01:L06-D052	B3 RM B336W SMOKE	Functional	Pass
240	2026-01-28	01:L06-D053	B3 EAST BY B335	Functional	Pass
241	2026-01-28	01:L06-D054	B3 ELEVATOR 5 LOBBY SMOKE	Functional	Pass
242	2026-01-28	01:L06-D055	B3 OUTSIDE RM B334 SMOKE	Functional	Pass
243	2026-01-28	01:L06-D056	B3 OUTSIDE RM B332 SMOKE	Functional	Pass
244	2026-01-28	01:L06-D057	B3 OUTSIDE RM B328 SMOKE	Functional	Pass
245	2026-01-28	01:L06-D058	B3 RM B328 SMOKE	Functional	Pass
246	2026-01-28	01:L06-D060	B3 RM B323 SMOKE	Functional	Pass
247	2026-01-28	01:L06-D062	B3 RM B319 SMOKE	Functional	Pass
248	2026-01-28	01:L06-D064	B3 OUTSIDE RM B321 SMOKE	Functional	Pass
249	2026-01-28	01:L06-D065	B3 OUTSIDE RM B319 SMOKE	Functional	Pass
250	2026-01-28	01:L06-D066	B3 BY RM B317 SMOKE	Functional	Pass

System Smoke Detectors (P)					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
251	2026-01-28	01:L06-D067	B3 VAULT RM B345 SMOKE	Functional	Pass
252	2026-01-28	01:L06-D068	B3 VAULT RM B345 SMOKE	Functional	Pass
253	2026-01-28	01:L06-D069	B3 OUTSIDE RM B337 SMOKE	Functional	Pass
254	2026-01-28	01:L06-D070	B3 RM B331 SMOKE	Functional	Pass
255	2026-01-28	01:L06-D071	B3 RM B331 SMOKE	Functional	Pass
256	2026-01-30	01:L06-D072	1ST FL RM 166Y SMOKE	Functional	Pass
257	2026-01-30	01:L06-D073	1ST FL RM 165 SMOKE	Functional	Pass
258	2026-01-30	01:L06-D074	1ST FL RM 165 SMOKE	Functional	Pass
259	2026-01-30	01:L06-D075	1ST FL RM 165 SMOKE	Functional	Pass
260	2026-01-30	01:L06-D076	1ST FL RM 165 SMOKE	Functional	Pass
261	2026-01-30	01:L06-D077	1ST FL RM 165 SMOKE	Functional	Pass
262	2026-01-30	01:L06-D078	1ST FL RM 165 FILE RM SMOKE	Functional	Pass
263	2026-01-30	01:L06-D079	1ST FL RM 165 FILE RM SMOKE	Functional	Pass
264	2026-01-29	01:L07-D029	B2 COMP RM CEILING B244	Functional	Pass
265	2026-01-29	01:L07-D030	B2 COMP RM CEILING B244	Functional	Pass
266	2026-01-29	01:L07-D031	B2 COMP RM CEILING B244	Functional	Pass
267	2026-01-29	01:L07-D032	B2 COMP RM CEILING B244	Functional	Pass
268	2026-01-29	01:L07-D033	B2 COMP RM CEILING B244	Functional	Pass
269	2026-01-29	01:L07-D034	B2 COMP RM CEILING B244	Functional	Pass
270	2026-01-29	01:L07-D035	B2 COMP RM CEILING B244	Functional	Pass
271	2026-01-29	01:L07-D036	B2 COMP RM CEILING B244	Functional	Pass
272	2026-01-29	01:L07-D037	B2 COMP RM CEILING B244	Functional	Pass
273	2026-01-29	01:L07-D038	B2 COMP RM CEILING B244	Functional	Pass
274	2026-01-29	01:L07-D039	B2 COMP RM CEILING B244	Functional	Pass
275	2026-01-29	01:L07-D040	B2 COMP RM CEILING B244	Functional	Pass
276	2026-01-29	01:L07-D041	B2 COMP RM CEILING B244	Functional	Pass
277	2026-01-29	01:L07-D042	B2 COMP RM CEILING B244	Functional	Pass
278	2026-01-29	01:L07-D043	B2 COMP RM CEILING B244	Functional	Pass
279	2026-01-29	01:L07-D044	B2 COMP RM CEILING B244	Functional	Pass
280	2026-01-29	01:L07-D045	B2 COMP RM CEILING B244	Functional	Pass
281	2026-01-29	01:L07-D046	B2 COMP RM CEILING B244	Functional	Pass
282	2026-01-29	01:L07-D047	B2 COMP RM CEILING B244	Functional	Pass
283	2026-01-29	01:L07-D048	B2 COMP RM CEILING B244	Functional	Pass
284	2026-01-29	01:L07-D049	B2 COMP RM CEILING B244	Functional	Pass
285	2026-01-29	01:L07-D050	B2 COMP RM CEILING B244	Functional	Pass
286	2026-01-29	01:L07-D051	B2 COMP RM CEILING B244	Functional	Pass
287	2026-01-29	01:L07-D052	B2 COMP RM CEILING B244	Functional	Pass
288	2026-01-29	01:L07-D053	B2 COMP RM CEILING B244	Functional	Pass
289	2026-01-29	01:L07-D054	B2 COMP RM CEILING B244	Functional	Pass
290	2026-01-29	01:L07-D055	B2 COMP RM CEILING B244	Functional	Pass
291	2026-01-29	01:L07-D056	B2 COMP RM CEILING B244	Functional	Pass
292	2026-01-29	01:L07-D061	B2 ELEVATOR 5 LOBBY SMOKE	Functional	Pass
293	2026-01-29	01:L07-D062	B2 ELEVATOR 5 LOBBY SMOKE	Functional	Pass
294	2026-01-29	01:L07-D063	B2 U1 DATA ROOM FRONT STRS SMOKE	Functional	Pass
295	2026-01-29	01:L07-D064	B2 U1 ELECTRIC ROOM FRONT STRS FLOOR	Functional	Pass
	Comment:	ELECTRIC ROOM FRONT STRS FLOOR B2			
296	2026-01-29	01:L07-D065	B2 N.EAST STAIR 2B UN1	Functional	Pass
297	2026-01-29	01:L07-D066	B2 AHU-14 MECH RM B244 SMOKE	Functional	Pass
298	2026-01-29	01:L07-D067	B2 AHU-14 MECH RM B244 SMOKE	Functional	Pass
299	2026-01-29	01:L07-D068	B2 OUTSIDE RM B249Z SMOKE	Functional	Pass

System Smoke Detectors (P)					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
300	2026-01-29	01:L07-D069	B2 ELEVATOR 3 & 4 LOBBY SMOKE	Functional	Pass
301	2026-01-29	01:L07-D070	B2 ELEVATOR 1 & 2 LOBBY SMOKE	Functional	Pass
302	2026-01-29	01:L07-D071	B2 OUTSIDE RM B251 SMOKE	Functional	Pass
303	2026-01-28	01:L07-D072	B2 ELEVATOR 9 LOBBY SMOKE	Functional	Pass
304	2026-01-29	01:L07-D073	B2 OUTSIDE RM B255Y SMOKE	Functional	Pass
305	2026-01-29	01:L07-D074	B2 OUTSIDE RM B256 SMOKE	Functional	Pass
306	2026-01-29	01:L07-D075	B2 OUTSIDE RM B258 SMOKE	Functional	Pass
307	2026-01-29	01:L07-D076	B2 HALL OUTSIDE RM B265 SMOKE	Functional	Pass
308	2026-01-29	01:L07-D077	B2 ELEVATOR 6 & 7 LOBBY SMOKE	Functional	Pass
309	2026-01-29	01:L07-D078	B2 RM B257 SMOKE	Functional	Pass
	Comment:	ELECTRICAL VAULT B257U			
310	2026-01-29	01:L07-D079	B2 MAIN FA PANEL RM B271	Functional	Pass
311	2026-01-29	01:L07-D080	B2 RM B270W SMOKE	Functional	Pass
	Comment:	ROOM B270Y			
312	2026-01-29	01:L07-D082	B2 RM B270W SMOKE	Functional	Pass
313	2026-01-29	01:L07-D084	B2 OUTSIDE RM B274 SMOKE	Functional	Pass
314	2026-01-29	01:L07-D085	B2 RM B260Y SMOKE	Functional	Pass
315	2026-01-29	01:L07-D086	B2 OUTSIDE RM B271 SMOKE	Functional	Pass
316	2026-01-28	01:L09-D003	ELEVATOR 9 UNSAFE (FREIGHT) EQUIPMENT RM SMOKE	Functional	Pass
317	2026-01-28	01:L09-D005	ELEVATOR 9 UNSAFE (FREIGHT) TOP OF SHAFT SMOKE	Functional	Pass
318	2026-01-28	01:L09-D008	B3 ELECTRICAL/DOA STROAGE RM B359	Functional	Pass
319	2026-01-28	01:L09-D009	B3 DOA STAGING RM B359A	Functional	Pass
320	2026-01-28	01:L09-D010	B3 MECHANICAL RM B337	Functional	Pass
321	2026-01-28	01:L09-D011	B3 FAR N. STORAGE RM B327	Functional	Pass
322	2026-01-28	01:L09-D012	B3 CORE N STORAGE RM B327	Functional	Pass
323	2026-01-28	01:L09-D013	B3 CORE N STORAGE RM B327	Functional	Pass
324	2026-01-28	01:L09-D014	B3 FAR S. STORAGE RM B327	Functional	Pass
325	2026-01-28	01:L09-D016	ELEVATOR 1 TOP OF SHAFT SMOKE	Functional	Pass
326	2026-01-26	01:L09-D018	ELEVATOR 1 & 2 EQ. RM.(PENT) UNSAFE SMOKE	Functional	Pass
327	2026-01-27	01:L09-D067	B1 B159 FIRE COMMAND CENTER SMOKE	Functional	Pass
328	2026-01-26	01:L09-D082	ELEVATOR 7 EQUIP RM UNSAFE HEAT	Functional	Pass
329	2026-01-28	01:L09-D143	E. ELEVATOR 5 TOP OF SHAFT UNSAFE HEAT	Functional	Pass
330	2026-01-26	01:L09-D151	CENT. ELEVATOR 1 EQUIP RM HEAT	Functional	Pass
331	2026-01-26	01:L09-D152	CENT. ELEVATOR 2 EQUIP RM HEAT	Functional	Pass
332	2026-01-28	01:L09-D155	CENT. ELEVATOR 3 TOP OF SHAFT UNSAFE SMOKE	Functional	Pass
333	2026-01-26	01:L09-D157	CENT. ELEVATOR 3 & 4 EQUIP RM UNSAFE SMOKE	Functional	Pass
334	2026-01-28	01:L10-D001	B3 RM B385 SMOKE	Functional	Pass
335	2026-01-28	01:L10-D002	B3 RM B385 SMOKE	Functional	Pass
336	2026-01-28	01:L10-D003	B3 HALL OUTSIDE RM B385 SMOKE	Functional	Pass
337	2026-01-28	01:L10-D004	B3 OUTSIDE RM B383 SMOKE	Functional	Pass
338	2026-01-28	01:L10-D005	B3 OUTSIDE RM B381X SMOKE	Functional	Pass
339	2026-01-28	01:L10-D006	B3 OUTSIDE RM B375X SMOKE	Functional	Pass
340	2026-01-28	01:L10-D007	B3 OUTSIDE RM B371 SMOKE	Functional	Pass
341	2026-01-28	01:L10-D008	B3 RM B371 SMOKE	Functional	Pass
342	2026-01-28	01:L10-D009	B3 RM B369 SMOKE	Functional	Pass
343	2026-01-28	01:L10-D010	B3 OUTSIDE RM B369 SMOKE	Functional	Pass
344	2026-01-28	01:L10-D012	B3 STAIRWELL BY RM B313	Functional	Pass
345	2026-01-28	01:L10-D013	B3 OUTSIDE RM B326 SMOKE	Functional	Pass
346	2026-01-28	01:L10-D015	B3 RM B355 SMOKE	Functional	Pass
347	2026-01-28	01:L10-D016	B3 RM B355 SMOKE	Functional	Pass

System Smoke Detectors (P)					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
348	2026-01-28	01:L10-D017	B3 ROOM OFF B353 SMOKE	Functional	Pass
349	2026-01-28	01:L10-D018	B3 RM B353 SMOKE	Functional	Pass
350	2026-01-28	01:L10-D019	B3 RM B351 MECH RM SMOKE	Functional	Pass
351	2026-01-28	01:L10-D020	B3 RM B351 MECH RM SMOKE	Functional	Pass
352	2026-01-28	01:L10-D021	B3 OUTSIDE RM B374 SMOKE	Functional	Pass
353	2026-01-28	01:L10-D022	B3 BY RM B370 SMOKE	Functional	Pass
354	2026-01-28	01:L10-D023	B3 RM B370 SMOKE	Functional	Pass
355	2026-01-28	01:L10-D024	B3 RM B370 SMOKE	Functional	Pass
356	2026-01-28	01:L10-D025	B3 RM B374 SMOKE	Functional	Pass
357	2026-01-28	01:L10-D026	B3 RM B386 MECH RM SMOKE	Functional	Pass
358	2026-01-29	01:L10-D027	B3 RM B386 MECH RM SMOKE	Functional	Pass
359	2026-01-29	01:L10-D028	B3 MECH RM AH-9 SMOKE	Functional	Pass
360	2026-01-29	01:L10-D029	B3 MECH RM AH-9 SMOKE	Functional	Pass
361	2026-01-29	01:L10-D030	B3 HALLWAY BY B356 SMOKE	Functional	Pass
362	2026-01-28	01:L10-D031	B3 ELEVATOR 9 LOBBY SMOKE	Functional	Pass
363	2026-01-28	01:L10-D032	B3 RM B386 SMOKE	Functional	Pass
364	2026-01-29	01:L10-D033	B3 RM B356 SMOKE	Functional	Pass
365	2026-01-29	01:L10-D034	B3 RM B356 SMOKE	Functional	Pass
366	2026-01-28	01:L10-D035	B3 RM B386 SMOKE	Functional	Pass
367	2026-01-28	01:L10-D036	B3 RM B386 SMOKE	Functional	Pass
368	2026-01-28	01:L10-D037	B3 RM B386 SMOKE	Functional	Pass
369	2026-01-28	01:L10-D038	B3 RM B386 SMOKE	Functional	Pass
370	2026-01-28	01:L10-D039	B3 RM B365 SMOKE	Functional	Pass
371	2026-01-29	01:L10-D042	B3 HALL BY RM B384	Functional	Pass
372	2026-01-28	01:L10-D043	B3 OUTSIDE BY RM B384	Functional	Pass
373	2026-01-28	01:L10-D044	B3 RM B365 SMOKE	Functional	Pass
374	2026-01-28	01:L10-D045	B3 RM B365 SMOKE	Functional	Pass
375	2026-01-28	01:L10-D046	B3 RM B385 SMOKE	Functional	Pass
376	2026-01-28	01:L10-D047	B3 RM B385 SMOKE	Functional	Pass
377	2026-01-28	01:L10-D048	B3 RM B365 SMOKE	Functional	Pass
378	2026-01-28	01:L10-D051	B3 RM B363 SMOKE	Functional	Pass
379	2026-01-28	01:L10-D052	B3 FREIGHT ELEVATOR BY B361 SMOKE	Functional	Pass
380	2026-01-28	01:L10-D053	B3 OUTSIDE RM B363 SMOKE	Functional	Pass
381	2026-01-28	01:L10-D054	B3 ELEVATOR 6 & 7 LOBBY SMOKE	Functional	Pass
382	2026-01-28	01:L10-D056	B3 OUTSIDE RM B357 SMOKE	Functional	Pass
383	2026-01-28	01:L10-D058	B3 RM B357 SMOKE	Functional	Pass
384	2026-01-28	01:L10-D059	B3 RM B357 SMOKE	Functional	Pass
385	2026-01-28	01:L10-D060	B3 RM B357 SMOKE	Functional	Pass
386	2026-01-28	01:L10-D061	B3 RM B357 SMOKE	Functional	Pass
387	2026-01-28	01:L10-D062	B3 RM B357 SMOKE	Functional	Pass
388	2026-01-28	01:L10-D063	B3 RM B355 SMOKE	Functional	Pass
389	2026-01-28	01:L10-D064	B3 RM B351 MECH RM SMOKE	Functional	Pass
390	2026-01-28	01:L10-D065	B3 OUTSIDE RM B351 SMOKE	Functional	Pass
391	2026-01-28	01:L10-D066	B3 RM 349Z SMOKE	Functional	Pass
392	2026-01-28	01:L10-D067	B3 ELEVATOR 1 & 2 LOBBY SMOKE	Functional	Pass
393	2026-01-28	01:L10-D068	B3 ELEVATOR 3 & 4 LOBBY SMOKE	Functional	Pass
394	2026-01-29	01:L10-D069	B3 RM B354 SMOKE	Functional	Pass
395	2026-01-29	01:L10-D070	B3 RM B352 SMOKE	Functional	Pass
396	2026-01-29	01:L10-D071	B3 RM B352 SMOKE	Functional	Pass
397	2026-01-29	01:L10-D072	B3 RM B354 SMOKE	Functional	Pass

System Smoke Detectors (P)					
Row	Date	Dev.#	Location	Visual/ Functional	Pass/ Fail
398	2026-01-29	01:L10-D073	B3 HALLWAY OUTSIDE B356 SMOKE	Functional	Pass
399	2026-01-28	01:L10-D074	B3 HALLWAY OUTSIDE B353 SMOKE	Functional	Pass
400	2026-01-29	01:L10-D075	B3 RM B358 SMOKE	Functional	Pass
401	2026-01-28	01:L10-D076	B3 RM B314 SMOKE	Functional	Pass
402	2026-01-28	01:L10-D078	B3 OUTSIDE RM 322 SMOKE	Functional	Pass
403	2026-01-28	01:L10-D079	B3 CAGE BESIDE B314 SMOKE	Functional	Pass
404	2026-01-28	01:L10-D080	B3 AH1-3 MECH RM B320U SMOKE	Functional	Pass
405	2026-01-28	01:L10-D081	B3 AH1-3 MECH RM B320U SMOKE	Functional	Pass
406	2026-01-28	01:L10-D082	B3 AH1-3 MECH RM B320U SMOKE	Functional	Pass
407	2026-01-28	01:L10-D083	B3 AH1-3 MECH RM B320U SMOKE	Functional	Pass
408	2026-01-28	01:L10-D084	B3 RM B342 SMOKE	Functional	Pass
409	2026-01-28	01:L10-D085	B3 RM B342 SMOKE	Functional	Pass
410	2026-01-29	01:L10-D086	B3 RM B354 SMOKE	Functional	Pass
411	2026-01-28	01:L10-D087	B3 OUTSIDE RM B342 SMOKE	Functional	Pass
412	2026-01-28	01:L10-D088	B3 OUTSIDE RM B345 SMOKE	Functional	Pass
413	2026-01-29	01:L10-D089	B3 OUTSIDE RM B347Y SMOKE	Functional	Pass
414	2026-01-28	01:L10-D090	B3 RM B347Y SMOKE	Functional	Pass
415	2026-01-28	01:L10-D091	B3 BY RM B315 SMOKE	Functional	Pass
416	2026-01-29	01:L10-D092	B3 OUTSIDE RM B356 SMOKE	Functional	Pass
417	2026-01-29	01:L10-D093	B3 OUTSIDE RM B354 SMOKE	Functional	Pass
418	2026-01-28	01:L10-D094	DUCT DETECTOR AHU-10	Functional	Pass
419	2026-01-28	01:L10-D095	DUCT DETECTOR AHU-10	Functional	Pass
420	2026-01-28	01:L10-D097	DUCT DETECTOR AHU-2 RETURN	Functional	Pass
421	2026-01-28	01:L10-D098	DUCT DETECTOR AHU-12 SUPPLY	Functional	Pass

See main System Record of Inspection and Testing for additional information, certifications, and approvals.

