



NOTES:

1. REFER TO CURRENT SPECIFICATION 5.15.11 (WATERMAIN INSTALL SPECS) FOR BRANCH INSTALLATION.
2. WATER SERVICE PIPING SHALL BE 6'-0" MIN. BELOW GRADE AND BE LEVEL WITH THE WATERMAIN.
3. WHERE AVAILABLE, ANCHOR TEES ARE PERMITTED.
4. COMM 82.40(8)(b) SHALL GOVERN ACCEPTABLE DISTANCES BETWEEN ANY SANITARY SEWER AND WATER SERVICE PIPING.
5. VALVE STOP BOXES SHALL BE A MAXIMUM OF 1" ABOVE FINISHED GRADE AND SHALL BE ACCESSIBLE IN UNPAVED AREAS.
6. VALVE STOP BOXES SHALL BE FLUSH WITH FINISHED GRADE IN PAVED AREAS.

WATER BRANCH SERVICE PIPE TAP
C### NTS

State of Wisconsin
Department of Administration
Division of Facilities Development



DFD Civil Details Library

Sheet Title:
WATER BRANCH SERVICE PIPE TAP

Revisions:

No.	Date:	Description:

Graphic Scale

DFD Number

Set Type

Date Issued **8/1/2017**

Sheet Number